

Jones Co  
F45  
5-25-70

Test Hole #4  
MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201

ELOG # 153

**CODED**

WATER WELL DRILLERS LOG

5/25 1970 C.P. Clark Jones

date well completed firm name county well located

LANDOWNER: City of Laurel  
Arbore Property  
(Formerly Robert Hearn (Plan))  
(mailing address)

description of formations encountered	from	to
Clay	0	8
Sand	8	45
Clay	45	75
Sand	75	134
Sand + Clay streaks	134	165
Sandy Clay	165	226
Sand	226	242
Clay	242	360
Sandy Clay	360	388
Sand	388	418
Sticky Clay	418	502

WELL LOCATION:  
sec 10 T 8N R 12 E  
300 yds S.W. of N.W. Runway  
(distance) (direction) (nearest town)

WELL PURPOSE: Test Hole  
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 4
  - (2) total depth (feet) 502
  - (3) static water level (feet) ? below top of ground
  - (4) casing None (material) (depth)
  - (5) screen None (length) (depth to top)
  - (6) pump None (HP) (yield gpm)
  - (7) electric log Yes (yes or no)  
Miss Geo Survey (organization running log)
  - (8) how well bottom plugged

**CODED**

MAY 29 1970

MISS. BD. OF WATER COMM.

DRILLERS REMARKS: