

JONES
 J43
 2-10-71

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

ELOG # 237

CODED

WATER WELL DRILLERS LOG

2/10 1971 C.P. Clark Jones
 date well completed firm name county well located

LANDOWNER: Matrasc of
Pine Grove Rt #
Ellisville Miss
 (mailing address)

description of formations encountered	from	to
Sandy Clay	0	15
Sandy clay gravel	15	26
Clay	26	95
Sand	95	108
Clay	108	214
Sand	214	359
Striky Clay	359	365
Clay with Sand streaks	365	420
Hard Clay (very Hard)	420	475
Sandy Clay	475	503
Sand	503	542
Spull Clay	542	575
Clay	575	630
Sand	630	675
Clay	675	809
Clay & Rock streaks	809	820
Solid Clay	820	850

WELL LOCATION:
 sec. 11 T. 10 N. R. 13 E.
2 1/2 miles W of Ellisville
 (distance) (direction) (nearest town)

WELL PURPOSE: Test Hole
 (home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (Inches) 2
 - (2) total depth (feet) 850
 - (3) static water level (feet) 178 below top of ground.
 - (4) casing Galv. Iron 665
 (material) (depth)
 (size) if telescope see back.
 - (5) screen 10, 665
 (length) (depth to top)
2 3/8, Solid SS #8 + 56t
 (size) (material) #16
 - (6) pump 2 5 1/2
 (HP) (yield gpm)
2200 S.P.
 (type power)
 - (7) electric log Yes
 (year or no)
State Geo Survey
 (organization running log)
 - (8) how well bottom plugged BWU

CODED

MAR 9 - 1971

MISC. DD. OF WATER

DRILLERS REMARKS: Set surface
Pipe to 48 to deal with
solid sand, had heavy
Clay between 48 + 95 ft. Mud would not stop hole
(P.H. 8 No Iron) Cased in every night