

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED JONES		PERMIT NUMBER
WELL NUMBER J 2024	CODED	NAME OF DRILLING FIRM Roy V. West
DATE WELL COMPLETED 4-28-98		

NAME & MAILING ADDRESS OF LANDOWNER
Crosbys Nursery

Moselle MS

WELL LOCATION	SEC	TOWNSHIP	RANGE
	32	7	N 13 E
DISTANCE	DIRECTION	NEAREST TOWN	
7 Miles	SW	of Ellisville	
OTHER LANDMARK			
WELL PURPOSE: Home, <input checked="" type="checkbox"/> Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P **7 1/2**

Pump Capacity (GPM)	No. of Stages	Setting Depth
80		160 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
270	4	250
Type of Casing	Hole Depth	Depth to Static Water Level
Pvc	270	112
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____		
WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): <input checked="" type="checkbox"/> Cement, Bentonite, or Mix		

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log _____

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	20	.010
Screen Type	Depth to Bottom - Feet	
Pvc	270	

Driller's Remarks _____

Top of Lap Pipe or Reduction in Casing _____

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	
			FROM	TO
SANDY CLAY	0	5		
SAND	5	42		
HARD CLAY	42	178		
SAND	178	270		

05-21-98A09:51 RCVD

IF MORE SPACE IS NEEDED, USE BACK