

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Jones

WELL NUMBER / CODED
N 2019

DATE WELL COMPLETED
7-27-93

PERMIT NUMBER

NAME OF DRILLING FIRM
Roy V. West

NAME & MAILING ADDRESS OF LANDOWNER
Larry Turner
Rt 1 Box 492
Oueh MS 39464

WELL LOCATION: SEC 23 TOWNSHIP 6 N S RANGE 14 E W

DISTANCE 10 Miles DIRECTION SW of NEAREST TOWN Ellisville

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine, Jet Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P 2

Pump Capacity (GPM)	No. of Stages	Setting Depth
<u>12</u>		<u>100'</u> FT.

PUMP TEST

Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth <u>125</u>	Casing Diameter (In.) <u>4</u>	Casing Length (Ft.) <u>115</u>
Type of Casing <u>PVC</u>	Hole Depth <u>125</u>	Depth to Static Water Level <u>70'</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches <u>4</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>.010</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>125'</u>	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>SANDY CLAY</u>	<u>0</u>	<u>32</u>			
<u>SAND</u>	<u>32</u>	<u>125</u>			

RECEIVED

DEC 23 1993

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK