

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631  
Jackson, MS 39289-0631

COUNTY WELL LOCATED  
**Kepler**

WELL NUMBER CODED  
**N-30013**

DATE WELL COMPLETED  
**7-23-02**

PERMIT NUMBER

NAME OF DRILLING FIRM  
**MEASDIAN, MS  
McDonald & Hix**

NAME & MAILING ADDRESS OF LANDOWNER  
**George Hopper  
100 Hoyer Rd**

Latitude: **DeKalb, MS.**  
Longitude:

WELL LOCATION SEC TOWNSHIP RANGE  
**16 10 (K) 16 (E)**  
**S W**

DISTANCE DIRECTION NEAREST TOWN  
**2 Miles S of DeKalb**

OTHER LANDMARK

WELL PURPOSE:  Home,  Irrigation,  Municipal,  Industrial,  Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):  
 Submersible  Turbine,  Jet  Flowing Well,  
Other (Describe)

POWER TYPE (Circle One):  
 Electric  Tractor,  Diesel,  Gasoline,  Butane,  
Other (Describe) **H/P 1/2**

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<b>Clay &amp; SAND</b>	<b>0</b>	<b>80</b>
<b>SAND, white # 12-14</b>	<b>80</b>	<b>120</b>
<b>Shale</b>	<b>120</b>	<b>180</b>

RECEIVED  
AUG 26 2002  
BY: OLWR

Top of Lap Pipe or Reduction in Casing  
FEET  IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

WELL DATA

Well Depth <b>140</b>	Casing Diameter (In.) <b>4</b>	Casing Length (Ft.) <b>120</b>
Type of Casing <b>PVC</b>	Ho... <b>140</b>	Depth to Static Water Level <b>75</b>

TYPE OF COMPLETION: (Circle One or More):  
 Gravel Packed,  Underreamed,  Telescoped,  
 Natural Development,  Open Hole,  Other  
(Describe)

WELL GROUTED TO A DEPTH OF **10** FEET  
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <b>4</b>	Length - Feet <b>20</b>	Slot Size - Inches <b>12</b>
Screen Type <b>PVC Saver</b>	Depth to Bottom - Feet <b>120</b>	

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

**Robert Hix #0-8** **7-29-02**  
Signature of Licensed Driller and License No. Date

Additional Information Required On Back