

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED LA FAYETTE		PERMIT NUMBER
WELL NUMBER A 2063	CODED	NAME OF DRILLING FIRM N. MS WELL DR
DATE WELL COMPLETED 11-16-00		B. Langford

NAME & MAILING ADDRESS OF LANDOWNER MR MURRY			
WARMON TOWN			
COMO MISS			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	2	6 N	5 W
DISTANCE	DIRECTION	NEAREST TOWN	
1.5	W	COMO	
OTHER LANDMARK close to N. SARDIS LAKE			
WELL PURPOSE <small>Home, Irrigation, Municipal, Industrial, Fish Pond, etc.</small>			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____		
Pump Capacity (GPM)	No of Stages	Setting Depth
12		120 FT.
PUMP TEST		
Well yielded 15 GPM with a drawdown of 3 ft. after 2 hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (in)	Casing Length (ft)
130	4	20
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	130	80' R 70
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____		
WELL GROUTED TO A DEPTH OF _____ FEET Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

SCREEN DATA		
Diameter - inches	Length - Feet	Slot Size - inches
4	10	1/16
Screen Type	Depth to Bottom - Feet	
PVC	130	

GEOLOGIC DATA (Office Use Only)			
Surface Elev	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Dirt	0	19			
clay	19	30			
shale	30	60			
clay	60	70			
shale	70	130			

REC'D JUN 11 2001

IF MORE SPACE IS NEEDED, USE BACK