

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

WELL NUMBER B 2039 CODED PERMIT NUMBER
 NAME OF DRILLING FIRM Leeper Drilling
 DATE WELL COMPLETED April 1995 Pontotoc

NAME & MAILING ADDRESS OF LANDOWNER
Baptist Family
Medical Clinic
Abbeville MS
 WELL LOCATION: SEC 34 TOWNSHIP 7 N RANGE 3 E
 DISTANCE 10 Miles North of Oxford
 OTHER LANDMARK
 WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Clinic

PUMP DATA
 PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe)
 POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P
 Pump Capacity (GPM) 10 No. of Stages 14 Setting Depth 189' FT.
 PUMP TEST
 Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA
 Well Depth 320' Casing Diameter (In.) 4" Casing Length (Ft.) 260'
 Type of Casing PVC Hole Depth 320' Depth to Static Water Level 140'
 TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)
 WELL GROUTED TO A DEPTH OF 10 FEET
 Type Grout (circle one): Cement, Bentonite, Mix

LOG DATA
 TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)
 Name of Organization Running Log

SCREEN DATA
 Diameter - Inches 2" Length - Feet 30' Slot Size - Inches .010
 Screen Type Slotted PVC Depth to Bottom - Feet 320'

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

 Driller's Remarks
 Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>TOP CLAY</u>	<u>0</u>	<u>20</u>			
<u>BLACK CLAY</u>					
<u>Blue clay</u>	<u>20</u>	<u>260</u>			
<u>Brown clay</u>					
<u>Green clay</u>					
<u>Silt</u>	<u>260</u>	<u>290</u>			
<u>SAND</u>	<u>290</u>	<u>320</u>			

DEC 11 1995
 Dept. of Environmental Quality
 Office of Land and Water Resources

IF MORE SPACE IS NEEDED, USE BACK PAGE