

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED 25 Mar	
WELL NUMBER A2084	CODED
DATE WELL COMPLETED 3-10-93	

PERMIT NUMBER 0-402
NAME OF DRILLING FIRM Tom Griffiths Water Well Inc.

NAME & MAILING ADDRESS OF LANDOWNER
**Richard Hartbeild
513 Hacienda Ave
Hattiesburg, Miss 39401**

WELL LOCATION: SEC **17** TOWNSHIP **S** RANGE **16**
N **S** **E**

DISTANCE **11** Miles **E** of **Columbia**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, **Jet** Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P **1**

Pump Capacity (GPM) 10	No. of Stages	Setting Depth 75 FT.
----------------------------------	---------------	--------------------------------

PUMP TEST
Well yielded **7** GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 90 FT	Casing Diameter (In.) 2 in	Casing Length (Ft.) 80
Type of Casing PVC	Hole Depth 90 FT	Depth to Static Water Level 50

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF **15** FEET
Type Grout (circle one): **Cement**, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): **No Log Run**
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2 in	Length - Feet 10	Slot Size - Inches .010
Screen Type PVC SLOT	Depth to Bottom - Feet 80-90	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS ENCOUNTERED	TO
Clay	0	40	RECEIVED	SEP 17 1993
Sand	40	90		

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK