MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Lamar
WELL NUMBER	B
CODED	2019
PERMIT NUMBER	O-586
NAME OF DRILLING FIRM	James Wells Water Well Ser.
DATE WELL COMPLETED	7-24-95

NAME & MAILING ADDRESS OF LANDOWNER
Joe Bryant
317 Big Hill Rd.
Sumrall, Mis 39482

WELL LOCATION	SEC	TOWNSHIP	RANGE
	5	5 N/S	15 E/W

DISTANCE	DIRECTION	NEAREST TOWN
5 Miles	N. East of	Sumrall

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 1

Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.

PUMP TEST

Well yielded 15 GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
225 FT	2 in	205

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	225 FT	75

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
2 in	20	008

Screen Type	Depth to Bottom - Feet
PVC SlOT	205-225

Top of Lap Joint Below Bottom Casing _____ FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

RECEIVED
SEP 01 1995
Dept. of Environmental Quality
Office of Land & Water Resources

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	2			
Clay	2	15			
Sand	15	30			
Clay	30	180			
Sand	180	225			
			IF MORE SPACE IS NEEDED, USE BACK		