

LAUDERDALE
F48
9-12-74

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

9.12.74 date well completed
McDonald + Hill firm name
Lauderdale county well located

LANDOWNER:
R. E. JONES

SEOULENA
(mailing address)

WELL LOCATION:
sec. 13 T. 7 N R. 14 E
DOWN TOWN SEOULENA
(distance) miles (direction) of (nearest town)

WELL PURPOSE: HOME
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 4"

(2) total depth (feet) 400'

(3) static water level (feet) 95' below top of ground.

(4) casing PVC 296' (material) (depth)
4" (size) if telescope see back.

(5) screen (length) (depth to top)
(size) (material)

(6) pump 1/2 Sub 10 (HP) (yield gpm)
E (type power)

(7) electric log (yes or no)
(organization running log)

(8) how well bottom plugged OPEN

description of formations encountered	from	to
CLAY	0	12
SHALE	12	85
SAND ST SHALE	82	120
SHALE	120	130
SAND ST SHALE	130	160
SHALE	160	225
CODED SAND	225	282
SHALE	282	345
SAND ST SHALE	345	400

RECEIVED
SEP 17 1974

DRILLERS REMARKS:

MISS. BD. OF WATER COMMISSIONERS