

LAUDERDALE
G
2047

**MISSISSIPPI
BOARD OF WATER COMMISSIONERS**
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

7-25-78 19 McDonald & Hill Lauderdale
 date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
Well No. 3			
US Corps of Engineers	shale	14	30
Pine Springs (mailing address)	sandy shale + sand	30	60
WELL LOCATION:	shale + lignite	60	100
sec. 8 T. 7 N. R. 15 E S W	sandy shale + sand	100	220
1 miles (distance) N (direction) of Pine Springs (nearest town)			
WELL PURPOSE: (home, irrigation, municipal, industrial)			
WELL COMPLETION DATA:			
(1) diameter (inches) 4"			
(2) total depth (feet) 220'			
(3) static water level (feet) 30' below top of ground.			
(4) casing PVC 95' (material) (depth)			
4" (size) if telescope see back.			
(5) screen (length) (depth to top)			
(size) (material)			
(6) pump 1/2 HP 10 (yield gpm)			
(type power)			
(7) electric log (yes or no)			
(organization running log)			
(8) how well bottom plugged open			
DRILLERS REMARKS:			

RECEIVED

JUL 31 1978

MISS. BD. OF WATER COMM