

AUDERDALE
J109
10-10-74
E. Coq #61
10-10-74 19

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

firm name McDONALD + Hill

county well located AUDERDALE

LANDOWNER: TOOMSUBA Water Assn.
TOOMSUBA MISS
 (mailing address)

WELL LOCATION:
 sec 24 T 7 N R 17 E
1/4 miles N of Toomsuba
 (distance) (direction) (nearest town)

WELL PURPOSE: Water System
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 6"
- (2) total depth (feet) 295'
- (3) static water level (feet) 93' below top of ground.
- (4) casing PVC 250'
 (material) (depth)
- (5) screen 30 250
 (length) (depth to top)
4" S. STEEL
 (size) (material)
- (6) pump 7.5 110
 (HP) (yield gpm)
Electric
 (type power)
- (7) electric log YES
 (yes or no)
- (8) how well bottom plugged _____
 (organization running log)

description of formations encountered	from	to
CLAY	0	22
SAND	22	58
SHALE	58	125
SHALE ST SAND	125	140
SAND	140	165
SHALE	165	240
SAND	240	278
SHALE	278	290
FINE SAND	290	295

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 DEC 9 1975

MISS. BD. OF WATER COMM

DRILLERS REMARKS:
21" = 4" BLACK PIPE
1 = 4X6 LEM SEAL