

**LAUDERDALE**  
**K 54**  
**7-12-74**

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

**CODED**

**WATER WELL DRILLERS LOG**

7-12-74 date well completed      1974 McDonald + Hill Inc firm name      Randolph county well located

LANDOWNER:  
Whitehead Dunnigan  
Rt #1 Toombs Co, Miss  
 (mailing address)

description of formations encountered	from	to
<u>clay</u>	<u>0</u>	<u>20</u>
<u>shale</u>	<u>20</u>	<u>30</u>
<u>st sand</u>	<u>30</u>	<u>135</u>
<u>shale</u>	<u>135</u>	<u>145</u>
<u>sandy</u>	<u>145</u>	<u>175</u>
<u>st fine sand</u>	<u>175</u>	<u>190</u>
<u>coarse sand</u>	<u>190</u>	<u>200</u>

WELL LOCATION:  
sec 17 T 7 N R 19 E  
 (distance) miles (direction) of (nearest town)

WELL PURPOSE:  
domestic  
 (home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 2
  - (2) total depth (feet) 200
  - (3) static water level (feet) 100 below top of ground.
  - (4) casing 2" PVC 194'  
 (material) (depth)  
no If telescope see back.  
 (size)
  - (5) screen 6' 194'  
 (length) (depth to top)  
2" plastic  
 (size) (material)
  - (6) pump \_\_\_\_\_ (HP) \_\_\_\_\_ (yield gpm)  
 (type power)
  - (7) electric log no  
 (yes or no)  
 (organization running log)
  - (8) how well bottom plugged back  
pressure value

**CODED**

**RECEIVED**  
 JUN 18 1974

DRILLERS REMARKS: none

MISS. BD. OF WATER COMM.