

1.17.7

LAUDERDALE
K 59
4-3-75

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

COLED

WATER WELL DRILLERS LOG

4.3.75 19 McDONALD LAUDERDALE
date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
<u>Rubin Buntor</u>	<u>CLAY</u>	<u>0</u>	<u>11</u>
<u>PHI THOMAS</u> (mailing address)	<u>P</u>	<u>11</u>	<u>14</u>
WELL LOCATION: sec <u>21</u> T <u>7</u> N R <u>12</u> E <u>2 1/2</u> miles <u>NEAST</u> <u>THOMAS</u> (distance) (direction) of (nearest town)	<u>SANDY</u>	<u>14</u>	<u>17</u>
WELL PURPOSE: (home, Irrigation, municipal, industrial)	<u>SHALE</u>	<u>17</u>	<u>64</u>
WELL COMPLETION DATA: (1) diameter (inches) <u>2"</u>	<u>SANDY ST SHALE</u>	<u>64</u>	<u>92</u>
(2) total depth (feet) <u>160'</u>	<u>SAND</u>	<u>92</u>	<u>120</u>
(3) static water level (feet) <u>24'</u> below above top of ground.	<u>SHALE</u>	<u>120</u>	<u>136</u>
(4) casing <u>PVC</u> <u>155'</u> (material) (depth)	<u>COURSE SAND</u>	<u>136</u>	<u>160</u>
<u>2"</u> If telescope see back. (size)			
(5) screen <u>5' #16</u> <u>155'</u> (length) (depth to top)			
<u>2"</u> <u>PVC</u> (size) (material)			
(6) pump <u>1/2 HP</u> <u>10</u> (HP) (yield gpm)			
<u>ELECTRIC</u> (type power)			
(7) electric log (yes or no)			
(organization running log)			
(8) how well bottom plugged <u>VALVE</u>			
DRILLERS REMARKS: <u>20' - 4" PVC / 160</u> <u>SURFACE PIPE</u> <u>Lost circulation 14'</u>			

RECEIVED
APR - 7 1975

MISS. BD. OF WATER COMM