

Lauderdale
P 30
12-20-74

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

12.20.74 19 McDONALD + WILL LAUDERDALE
date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---|---------------------------------------|------|-----|
| MRS BARBARA LIGHTSEY | CLAY ST SAND | 0 | 35 |
| R#1 BOX 256 CUBA ALA (mailing address) | SHALE | 35 | 60 |
| WELL LOCATION: sec. 3 T. 6 N R. 18 E 2 miles SOUTH KEWANEE (distance) (direction) (nearest town) | SAND | 60 | 80 |
| WELL PURPOSE: HOME (home, irrigation, municipal, industrial) | SHALE | 80 | 130 |
| WELL COMPLETION DATA: (1) diameter (inches) 4" | SAND ST SHALE | 130 | 160 |
| (2) total depth (feet) 230 | SHALE | 160 | 163 |
| (3) static water level (feet) 57' below top of ground. | FINE SAND | 163 | 220 |
| (4) casing PVC 110' (material) (depth) | COURSE SAND | 220 | 230 |
| 4" If telescope see back. (size) | | | |
| (5) screen 10' 220' (length) (depth to top) | | | |
| 2" PVC (size) (material) | | | |
| (6) pump 1/2 sub 10 (HP) (yield gpm) | | | |
| Electric (type power) | | | |
| (7) electric log (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged VALVE | | | |
| DRILLERS REMARKS: 70' = 2" PVC 1 = 4 X 3 RUBBER SEAL | | | |

RECEIVED

JAN 21 1975

MISS. Bd. of Water Comm