

AUDERDALE
Q 2004
4-13-77

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

4-13-77 ^{13P} McDonald + Hill Auderdale
 date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
(mailing address)			
<u>Strom House Baptist Church</u>	<u>Clay</u>	<u>0</u>	<u>20</u>
	<u>sand + clay</u>	<u>20</u>	<u>45</u>
	<u>shale</u>	<u>48</u>	<u>80</u>
	<u>Rock + shale</u>	<u>80</u>	<u>95</u>
	<u>green sand sandy shale</u>	<u>95</u>	<u>110</u>
	<u>shale + Rock</u>	<u>110</u>	<u>225</u>
	<u>sand</u>	<u>225</u>	<u>260</u>

WELL LOCATION:
 sec. 8 T. 5 N. R. 14 E.
SW of Merida
 (distance) miles (direction) (nearest town)

WELL PURPOSE: home
 (home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- diameter (inches) 4"
 - total depth (feet) 260'
 - static water level (feet) 80' below top of ground.
 - casing PVC, 75' (material) (depth)
4" if telescope see back. (size)
 - screen (length) (depth to top)
 (size) (material)
 - pump 1/2 60 gpm (HP) (yield/gpm)
E (type power)
 - electric log (yes or no)
 (organization running log)
 - how well bottom plugged open

RECEIVED

APR 18 1977

DRILLERS REMARKS: