MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Lawrence
WELL NUMBER	B
CODED	2008
DATE WELL COMPLETED	4-26-95
PERMIT NUMBER	0-586
NAME OF DRILLING FIRM	James Wells Water Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
J.D. White
P.O. Box 1098
Monticello Miss 39654

WELL LOCATION	SEC	TOWNSHIP	RANGE
	31	9 N S	20 E W

DISTANCE	DIRECTION	NEAREST TOWN
5 Miles	West of	New Hebron

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 1

Pump Capacity (GPM)	No. of Stages	Setting Depth
		140 FT.

PUMP TEST

Well yielded 15 GPM with a drawdown of ____ ft. after ____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
165	4 in	145

Type of Casing	Hole Depth	Depth to Static Water Level
P.V.C.	165	120

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF ____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4 in	20	10

Screen Type	Depth to Bottom - Feet
P.V.C. slot	145-165

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	3
Clay	3	40
Sand	40	60
Clay	60	80
Sand and Pea Gravel	80	165

FORMATIONS (Continued)	FROM	TO

RECEIVED
JUN 02 1995
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK