

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
L. Lawrence

WELL NUMBER CODED
B 2010

DATE WELL COMPLETED
5-29-96

PERMIT NUMBER
0-586

NAME OF DRILLING FIRM
James Wells

Water Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
J.R. Blackman

Rt1 Box 38c

Newhebron, Miss 39140

WELL LOCATION SEC TOWNSHIP RANGE
20 9 N 20 E

DISTANCE DIRECTION NEAREST TOWN
0 Miles 0 of New Hebron

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P _____

Pump Capacity (GPM) No. of Stages Setting Depth
_____ FT.

PUMP TEST
Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
80 2 in 70

Type of Casing Hole Depth Depth to Static Water Level
PVC 80 25

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

RECEIVED

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) **JUN 25 1996**

Name of Organization Running Log
Dept. of Environmental Quality
Office of Land & Water Resources

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
2 in 10 08

Screen Type Depth to Bottom - Feet
PVC SLOT 70-80

GEOLOGIC DATA

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top

Subs. SWL Date Analysis Aquifer Test

Driller's Remarks
Casing only

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Top Soil	0	2			
Clay	2	25	own		
Sand/gravel	25	80	run		

IF MORE SPACE IS NEEDED, USE BACK