Ctoto XX	All Donont	
	ell Report For Office Use Only:	
	art 1	
Permit #: Office of Land a	Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Well #:	
	IS 39289-0631 L. S. Elevation:	
Press artitude anti-	961-5210 4-6938 (fax) B-log #:	
(601)35	4-6938 (fax) B-log #:	
State Law requires that this report be prepared by the 30 days of completion of drilling of the well.	driller in detail and filed with the Department within	
Well Owner Information	Well Location	
Owner Name Donnie Weeks	Latitude: 31.32. 2. Longitude: 90.12.796"	
Mailing Address: 465 Ford Calcote Rd	Method of Lat/Long (circle one): Conventional Survey,	
	USGS quad, Hand-held GPS, Survey-grade GPS	
Monticello MS 39654 City State Zip Code	NE14 SE14 Sec 29 TWR JAL Rug WE	
Telephone No. <u>601 587 - 1366</u>	Distance Direction Nearest Town 	
Well		
Purpose of Well (circle one Home Industrial Public Supply		
Date well drilling started: <u>4/15/09</u> Date	well drilling completed: <u>4/15/09</u>	
If flowing, method of flow regulation: Valve Other (
Static Water Level: _/ O O feet above of below circle one)		
Method of Measurement (circle one) steel tape clectric tap	-	
Hole depth:	_ Well grouted to a depth of feet	
-Type of grout (circle one): Cement Bentonite Min		
Casing length: <u>167</u> feet Casing diameter: <u>4</u>	inches Type of casing:	
Screen length:feet Screen diameter:		
Screen slot size: <u>-O/O</u> inches Setting depth: From		
Type of completion (circle all applicable): Gravel packed Und	· · · · · · · · · · · · · · · · · · ·	
Other (describe):		
Top of lap pipe or reduction in casing:feet. If		
Logs run (circle all applicable): No log run Electric Gamma Ra	y Density Sonic Neutron Other:	
Name of organization running log(s):		
	accordance with all applicable requirements of the Mississippi	
Department of Environmental Quality and/or the Mississippi D	epartment of Health regulations and state laws.	
GRENN WATER WELL & SUPPLY, INC.	Q - MAcrt. 1	
Brian McClendon, lic. no. 0-664	Drug IVF Chugos	
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor	
	RECEIVE	

. •

MAY 0 4 2009

)

BY: OLWR

۲.,

If well telescopes please sketch be	elow and show depths.		F-,	27
Ground Level		Description of Formations Encountered	From	To 72
~		red clay	72	98
· · •		mostly sandt gravel	98	175
		vallow clay (hard)	178	18
				
				╞
				+
				╞
				F
				╞

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; , ***** 4) indicate direction. Ę 0 00 Landowner Name:

Signature of Water Well Contractor

Brian McClendon, lic. no. 0-664 GRENN WATER WELL & SUPPLY, INC.

STATE WI	ELL REPORT
County: Lawrence Pump Installer' Permit #: Office of Land Driller: GRENN WATER WELL & Jackson, N SUPPLY / INC, 09 (601	Part 2 For Office Use Only: s Completion Report Aquifer: and Water Resources Mage: Aquifer: Box 10631 Well #: F-27 y861-5210 Elevation: 54-6938 (fax) Elevation: well and filed with the Department within 30 days of the Well Location
Well Owner Information	Latitude: <u>31⁰32'665</u> Longitude: <u>90'12'736</u>
Owner Name: Doiny Weeks	Method of Lat/Long (circle one): Conventional Survey,
Mailing Address: <u>465 Ford Calcore Red</u>	USGS quad, <u>Hand-held GP3</u> , Survey-grade GPS
<u>Montreello MS 39654</u>	<u>NE 14 SE 14 Sec 29 Twn 7 N Rng JUE</u>
City State Zip Code	Distance Direction Nearest Town
Telephone No. (601) 587-1366	<u>5 Miles W of Montrice II 6</u>
Pump Type	Power Type
Circle one Air Lift Jet Submersible Bucket Piston Turbine Centrifugal Rotary Flowing Well Other (specify):	Circle one Diesel Engine Gasoline Engine Natural Gas Electric Motor Hand Tractor PTO Windmill Other (specify):
Pump Test Data Date Well Tested: $4/17/09$ Static Water Level (A): 100 Feet Below Land Surface Pumping Water Level (B): 107 Feet Below Land Surface Drawdown [(B) - (A)]: 7 Feet Below Land Surface Test Pumping Rate: 12 Gallons Per Minute Duration of Pump Test (minimum 4 hours): 4 hours	Method of Measuring Water Level Circle one Air Line Electric Measuring Line Steel Tape Other (specify):
I HEREBY CERTIFY that the above statements are true to the best	of my knowledge.
GRENN WATER WELL & SUPPLY, INC.	<u>William</u> Hardin
WILLIAM L. HARDIN, LIC. NO. 0-802	Signature of Pump Installer
Print Name of Pump Installer and License No. (if applicable)	RECE

•

r A

- MAY 0 4 2009
- BY: OLWR