

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED LAWRENCE
WELL NUMBER CODED P-2080
DATE WELL COMPLETED 5-5-98

PERMIT NUMBER 0-287
NAME OF DRILLING FIRM Reever Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER Chad Smith			
WELL LOCATION: SEC 28 TOWNSHIP 7 RANGE 10			
DISTANCE 6 Miles DIRECTION W of NEAREST TOWN Monticello			
OTHER LANDMARK			
WELL PURPOSE: <u>Home</u> , Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 12		
Pump Capacity (GPM) 10	No. of Stages 8	Setting Depth 120 FT.
PUMP TEST		
Well yielded 50 GPM with a drawdown of 0 ft. after 1 hours of pumping		

WELL DATA		
Well Depth 130'	Casing Diameter (In.) 4"	Casing Length (Ft.) 20'
Type of Casing PVC	Hole Depth 130'	Depth to Static Water Level 90'

LOG DATA	
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) 10 Gal sand	
WELL GROUTED TO A DEPTH OF 20 FEET Type Grout (circle one): <u>Cement</u> , Bentonite, or Mix	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches 10 Thds.
Screen Type PVC	Depth to Bottom - Feet 130'	

Driller's Remarks	
Top of Lap Pipe or Reduction in Casing	
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
clay	0	18
sand & gravel	18	60
chalk	60	110
sand & gravel	110	130

FORMATIONS (Continued)	FROM	TO
RECEIVED		
JUN 28 1999		
Dept. of Environmental Quality Office of Land & Water Resources		
IF MORE SPACE IS NEEDED, USE BACK		

