

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
LAWRENCE

WELL NUMBER
H-2015

DATE WELL COMPLETED
9-17-99

PERMIT NUMBER
0-586

NAME OF DRILLING FIRM
James Wells

Water Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
Willie Hollins JR.

RT 1 Box 1129-A

Silver Creek, MS 39663

WELL LOCATION SEC TOWNSHIP RANGE
11 7 S 20 E

DISTANCE DIRECTION NEAREST TOWN
2 Miles East of Silver Creek

OTHER LANDMARK

WELL PURPOSE Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) **H/P 2**

Pump Capacity (GPM) No. of Stages Setting Depth
_____ FT.

PUMP TEST
Well yielded **35** GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 130 FT	Casing Diameter (Inch) 4 in	Casing Length (Ft.) 110
Type of Casing PVC	Hole Depth 130 FT	Depth to Static Water Level 50

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe) _____

WELL GROUTED TO A DEPTH OF **15** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4 in	Length - Feet 20	Slot Size - Inches .008
Screen Type PVC 510T	Depth to Bottom - Feet 110-130	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
RECEIVED

Top of Lap Pipe or Reduction in Casing
111 20 2000
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Topsoil	0	3	Dept. of Environmental Quality Office of Land & Water Resources		
Clay	3	80			
Sand	80	130			

IF MORE SPACE IS NEEDED, USE BACK