

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED LAWRENCE	
WELL NUMBER L 2024	PERMIT NUMBER 0-586
CODED	NAME OF DRILLING FIRM James Wells
DATE WELL COMPLETED 10-23-95	Water Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
Timothy Nations
PO Box 1721
Monticello, Miss 39654

WELL LOCATION SEC TOWNSHIP RANGE
25 6 N 20 S

DISTANCE DIRECTION NEAREST TOWN
1 Miles **N.W.** of **OAKVALE**

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P _____

Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.

PUMP TEST
Well yielded _____ **12** GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 140	Casing Diameter (In.) 4	Casing Length (Ft.) 120
Type of Casing PVC	Hole Depth 140	Depth to Static Water Level 80

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other (Describe) _____

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4	Length - Feet 20	Slot Size - Inches 120
Screen Type PVC SLOT	Depth to Bottom - Feet 120-140	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Topsoil	0	2
Clay	2	40
Sand	40	70
Clay	70	80
Sand	80	140

RECEIVED

JAN 08 1996

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK