

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
LAWrence

WELL NUMBER
L-2037

DATE WELL COMPLETED
2-28-2000

PERMIT NUMBER
0-586

NAME OF DRILLING FIRM
JAMES WELLS

WATER WELL SERVICE

NAME & MAILING ADDRESS OF LANDOWNER
Steadmon Duhon

Rt 1 Box 137

oakdale Ms.

WELL LOCATION SEC TOWNSHIP RANGE
12 6 N 20 E

DISTANCE DIRECTION NEAREST TOWN
5 Miles north of OAKDALE Ms.

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) **H/P**

Pump Capacity (GPM) No of Stages Setting Depth
_____ FT.

PUMP TEST
Well yielded **15** GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth 80	Casing Diameter (in) 4in	Casing Length (ft) 80
Type of Casing PVC	Mole Depth 80	Depth to Static Water Level 55

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

WELL GROUTED TO A DEPTH OF **15** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - inches 4in	Length - Feet 20	Slot Size - inches 800
Screen Type PVC	Depth to Bottom - Feet 60-80	

GEOLOGIC DATA (Office Use Only)

Surface Elev	Geologic Unit	Unit Thickness	Depth to Top
Subs SWL	Date	Analysis	Aquifer Test

Driller's Remarks

RECEIVED

Top of Last Screen Reduction in Case of _____ FEET
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM TO		FORMATIONS (Continued)	FROM TO	
	FROM	TO		FROM	TO
Top Soil	0	2			
CL	2	20			
Red Sand	20	80			

Feb. 28 2000
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK