

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Lawrence
WELL NUMBER 2013 CODED

DATE WELL COMPLETED
6-25-88

PERMIT NUMBER _____
NAME OF DRILLING FIRM
Green Water Well & Supply Inc.

NAME & MAILING ADDRESS OF LANDOWNER
Jopie Smith

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____

Pump Capacity (GPM)	No. of Stages	H/P
<u>20</u>	<u>18</u>	<u>90</u>

Setting Depth _____ FT.

PUMP TEST
Well yielded 20 GPM with
a drawdown of 0 ft.
after 2 hours of pumping

WELL LOCATION: SEC _____ TOWNSHIP _____ RANGE _____
DISTANCE 2 Miles DIRECTION NE of NEAREST TOWN Jopie
OTHER LANDMARK _____

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

WELL DATA

Well Depth <u>128</u>	Casing Diameter (In.) <u>4</u>	Casing Length (Ft.) <u>108</u>
Type of Casing <u>PVC</u>	Hole Depth <u>135</u>	Depth to Static Water Level <u>60</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other _____

Top of Lap Pipe or Reduction in Casing _____ FEET
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) No Log Run

Name of Organization Running Log _____

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks _____

SCREEN DATA

Diameter - Inches <u>4</u>	Length - Feet <u>20</u>	Slot Size - Inches <u>.010</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>128</u>	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FORMATIONS (Continued)	
	FROM	TO
<u>Citronelle</u>	<u>0</u>	<u>128</u>
<u>Clay</u>	<u>128</u>	<u>135</u>

RECEIVED

SEP 16 1988

Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK