

CODED

Leake
A6
12-66
Elec Log 66

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

December 14, 1966 Layne-Central Company, Leake
date well completed firm name county well located

LANDOWNER: Thomastown	description of formations encountered	from	to
Domestic Water System, Inc.			
Thomastown, Mississippi	Red Clay	0	10
(mailing address)	Pink Chalk	10	36
	Hard Clay	36	62
	Sandy Shale	62	120
	Sand	120	160
	Clay	160	184
	Sand	184	252

WELL LOCATION:
sec. 27 T. 12 N. R. 6 E.
1/4 miles East of town
(distance) (direction) (nearest town)

WELL PURPOSE: domestic
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:
(1) diameter (inches) 8"
(2) total depth (feet) 251'

(3) static water level (feet) 164' below top of ground.

(4) casing 8" (material) 206' (depth)
if telescope see back.

(5) screen 40' (length) 206' (depth to top)
6" (size) stainless steel (material)

(6) pump 15 (HP) 155 (yield gpm)
electric (type power)

(7) electric log Yes (yes or no)

Miss. Geological Survey (organization running log)

(8) how well bottom plugged valve

from compl. record
from log.
66 Regard Luckett
drawdown 20'
pH - 5.2 (lab)
Fe - 0.2
Cl - 5
CO₂ - 165



DRILLERS REMARKS:
capacity test has not been run as of this date.