

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Leake	
WELL NUMBER 2229	CODED
DATE WELL COMPLETED 6-26-90	

PERMIT NUMBER
NAME OF DRILLING FIRM THOMAS DRILLING
206 GRAHAM ST.
CARTHAGE, MISS. 39051

NAME & MAILING ADDRESS OF LANDOWNER Gillie Myrick			
Rt. 7 Box 296			
Carthage, MS 39051			
WELL LOCATION:	SEC	TOWNSHIP	RANGE
	30	12	8
		N	E
		S	W
DISTANCE	DIRECTION	NEAREST TOWN	
1 1/2 Miles	SSE	Singleton	
OTHER LANDMARK 1/2 mi. W of Church			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. Home			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P		
Pump Capacity (GPM) 8	No. of Stages 2	Setting Depth 60 FT.
PUMP TEST		
Well yielded 8 GPM with a drawdown of 10 ft. after 1 hours of pumping		

WELL DATA		
Well Depth 84'	Casing Diameter (In.) 2	Casing Length (Ft.) 74'
Type of Casing PVC	Hole Depth 84'	Depth to Static Water Level 40'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)		
Top of Lap Pipe or Reduction in Casing - FEET		
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, No Log Run , Neutron, Other (Describe)	
Name of Organization Running Log	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			

SCREEN DATA		
Diameter - Inches 2	Length - Feet 10	Slot Size - Inches .10
Screen Type PVC Wrapped	Depth to Bottom - Feet 84'	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Red Dirt & Clay	0	10	RECEIVED JUN 28 1990 Department of Natural Resources Bureau of Land & Water Resources		
Yellow Sand Coarse	10	30			
Fine White Sand	30	60			
Coarse White Sand	60	84			

IF MORE SPACE IS NEEDED, USE BACK