County: LEAKE
Permit #:
Driller: Thomas Drilling
Date drilling completed: 7-27-05

Well Driller Report and Well Log

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

For Office Use Only:		
Aquifer: Well #:		
E-log #:		

30 days of completion of drilling of the well.	ornier in detail and med with the Department within			
Well Owner Information	Well Location			
Owner Name Tony Squell #4	Latitude 37.987. Longitude: 89.28.528.			
Mailing Address: 3120 Reformation Rd	Method of Lat/Long (circle one): Conventional Survey,			
	USGS quad, Hand-held GPS, Survey-grade GPS			
Carthage MS 39051 City State Zip Code	6/4 SE 1/4 Sec 21 V Twn // N Rng 8 E			
Telephone No. ()	Distance Direction Nearest Town 2 Miles NE of Carthage			
	/			
Well				
Purpose of Well (circle one) Home Industrial Public Supply				
Date well drilling started: 8-27-05 Date well drilling completed: 8-27-05				
If flowing, method of flow regulation: Valve Other	(describe)			
Static Water Level: 40 feet a or below (circle one) land surface Date measured: 8-27-05				
Method of Measurement (circle one) steel tape electric ta	pe zit line other:			
Hole depth: Z80 Well depth: Z80 Well grouted to a depth of 10 feet				
Type of grout (circle one): Cement Bentonite Mix				
Casing length:feet Casing diameter:inches Type of casing:				
Screen length: ZO feet Screen diameter: 4 inches Type of screen:				
Screen slot size: inches Setting depth: From 260 feet to feet				
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development				
Other (describe):				
Top of lap pipe or reduction in casing:feet. If telescoped or more than one screen, describe on back of page				
Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other:				
Name of organization running log(s):				
I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of				
Environmental Quality and/or the Mississippi Department of Health regulations and state laws.				
David S. Thomas 0-147	Jan & Thousen			
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor			

Ground Level	Description of Formations Encountered	From	То
	Mixed Clay	0	20
	SAND White	20	65
	Grav Clar	65	142
	Green SANd	142	150
	Rock & Green SAND	150	120
	Green SAND	130	189
	Gray SAND W/specks of G	res /89	210
	Clay & Rock	· · ·	2/2
	Gray SAND Med. COAKS		
	7 7 57		
			1
			
			ļ
			ļ
	-		
1	\		<u></u>

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; 4) indicate direction.				
4				
Landowner Name: Tony	Savell			

Signature of Water Well Contractor

STATE WELL REPORT

Part 2

Pump Installer's Completion Report

County: Leake Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Date completed: 8-30 Jackson, MS 39289-0631

For Office Use Only: Aquifer: Well #: Elevation:

(601)354-6938 (fax)

(601)961-5210

This report must be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump. A copy of Part 1 of this report must be attached to this report.			
Well Owner Information	Well Location		
Owner Name: Tony Savell #4 Mailing Address: 3120 Reformation Rd	Latitude: Longitude:		
Mailing Address: 3120 Reformation Rd	Method of Lat/Long (circle one): Conventional Survey,		
	USGS quad, Hand-held GPS, Survey-grade GPS		
CArthage M5 3905/ City State Zip Code	¼ Gec 21 Twn //N Rng 8 E		
City / State Zip Code	Distance Direction Nearest Town		
Telephone No. ()	Z Miles NE of CArthage		
Proper Trans			
Pump Type Circle one	Power Type Circle one		
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas		
Bucket Piston Turbine	Electric Motor Hand Tractor PTO		
Centrifugal Rotary Flowing Well	Windmill Other (specify):		
Other (specify):	Horse Power Rating of Motor: /2		
Date Pump Installed: 8-30-05	Setting Depth:feet		
Rated Pump Capacity:Gallons Per Minute	Number of Stages:		
Pump Test Data	Method of Measuring Water Level		
Date Well Tested:	Circle one		
Static Water Level (A): 40 Feet Below Land Surface	Air Line Electric Measuring Line Steel Tape		
Pumping Water Level (B): 80 Feet Below Land Surface	Other (specify):		
Drawdown [(B) – (A)]: 40 Feet Below Land Surface	For flowing well, measured shut in head:feet		
Test Pumping Rate: 30 Gallons Per Minute	Well yieldedGPM with a drawdown of		
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping		
I HEREBY CERTIFY that the above statements are true to the best of my knowledge On Some of Pump Installer and License No. (if applicable) Signature of Pump Installer			