

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Leake

WELL NUMBER
V-35

CODED

DATE WELL COMPLETED
1-28-04

PERMIT NUMBER

NAME OF DRILLING FIRM
Thomas Drilling

NAME & MAILING ADDRESS OF LANDOWNER
Dale Quick

1804 Hwy 16 E

Latitude:

Longitude: CANTHAR MS 39051

WELL LOCATION SEC 15 TOWNSHIP 10 RANGE 2

DISTANCE 2.7 MILES DIRECTION West of NEAREST TOWN CANTHAR

OTHER LANDMARK
1/2 Miles N. of Pearl R.

WELL PURPOSE (Home, Irrigation, Municipal, Industrial, Fish Pond, etc.)

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 1/2

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Yellow Clay</u>	<u>0</u>	<u>9</u>
<u>6" of Sand</u>	<u>9</u>	<u>12</u>
<u>Gray Clay</u>	<u>12</u>	<u>79</u>
<u>Thin Gray Sand</u>	<u>79</u>	<u>92</u>
<u>Gray Clay</u>	<u>92</u>	<u>114</u>
<u>Gray Sand</u>	<u>114</u>	<u>165</u>

RECEIVED
FEB 09 2004
BY: OLWR

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

WELL DATA

Well Depth: 165' Casing Diameter (In.): 4" Casing Length (Ft.): 155'

Type of Casing: PVC Hole Depth: 165' Depth to Static Water Level: 65'

TYPE OF COMPLETION: (Circle One or More)
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one) Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches: 4" Length - Feet: 10' Slot Size - Inches: .010

Screen Type: PVC Saver Depth to Bottom - Feet: 165'

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Paul J. Thomas 0-147
Signature of Licensed Driller and License No.

1/28/04
Date

Additional Information Required On Back