County: Leake
Permit #:
Driller thomas Drilling
Date drilling completed: 11-9-04

Well Driller Report and Well Log

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

For Office Use Only:		
Aquifer:		
well #: <u>K-37</u>		
L. S. Elevation:		
E-log #:		

State Law requires that this report be prepared by the driller in detail and filed with the Department within

30 days of completion of drilling of the well.	•			
Well Owner Information	Well Location			
Owner Name Shad Alford	Latitude: 32° 40,595 " Longitude: 89°33,891"			
Mailing Address: 643 Alford Rd	Method of Lat/Long (circle one): Conventional Survey,			
	USGS quad, Hand-held GPS, Survey-grade GPS			
Carthage MS 39051 City State Zip Code	NW 1/4 NE 1/4 Sec 29 Twn 10 N Rng 7E			
Telephone No. (601) 9/17 - 9203	Distance Direction Nearest Town Miles South of Carthage			
Well	Data /			
Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: Poultry				
Date well drilling started: $1/-9-04$ Date well drilling completed: $1/-9-04$				
If flowing, method of flow regulation: Valve Other (describe)				
Static Water Level: 45 feet above or below (circle one) land surface Date measured: 11-9-04				
Method of Measurement (circle one) steel tape electric tape dir line other:				
Hole depth: 150' Well depth: 150' Well grouted to a depth of 10 feet				
Type of grout (circle one): Cement Bentonite Mix				
Casing length:feet Casing diameter:inches Type of casing:				
Screen length: 10 feet Screen diameter: 4 inches Type of screen: PUC				
Screen slot size:oloinches Setting depth: Fromfeet tofeet				
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development				
Other (describe):				
Top of lap pipe or reduction in casing:feet. If telescoped or more than one screen, describe on back of page				
Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other:				
Name of organization running log(s):	ith all and inch a requirements of the Ministration Department of			
I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.				
David S. Thomas 0-147	Jan B. Homorewen			
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor			

Ground Level	1<-37
	7

(79)

Description of Formations Encountered	From	То
Yellow Clay Yellow Sand Fine Gray Sand Good Gray Sand	0	20
Yellow Sand	20	45
Fine Gray Sand	45	110
Good Gray Sand	110	150
7		
	**	
11.800		
· · · · · · · · · · · · · · · · · · ·	·	

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; 4) indicate direction.

4) indicate direction.

Well

Micken Houses

Landowner Name: Shad Alford

Signature of Water Well Contractor

RECEIVED

NOV 16 2004

BY: OLWR

STATE WELL REPORT Part 2

Pump Installer's Completion Report

County: LOAKO

Permit #:

Driller: Thomas Drilling

Date completed: //- 9-04

Print Name of Pump Installer and License No. (if applicable)

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631

Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

This report must be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump. A copy of Part 1 of this report must be attached to this report.

Well Owner Information	Well Location			
Owner Name: Shad Altord	Latitude: <u>W32°40.575</u> Longitude <u>W089°33.871</u>			
Mailing Address: 643 Alford Rd.	Method of Lat/Long (circle one): Conventional Survey,			
C. 11 M5 39x1	USGS quad, Hand-held OPS, Survey-grade GPS 4 Sec 27 Twn 10N Rng 7E			
Carthage M5 39051 City State Zip Code				
	Distance Direction Nearest Town			
Telephone No. 601) 911 - 9203	2 Miles South of Carthage			
Pump Type Circle one	Power Type Circle one			
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas			
Bucket Piston Turbine	Electric Motor Hand Tractor PTO			
Centrifugal Rotary Flowing Well	Windmill Other (specify):			
Other (specify):	Horse Power Rating of Motor: 1/2			
Date Pump Installed:	Setting Depth:feet			
Rated Pump Capacity:Gallons Per Minute	Number of Stages://			
Pump Test Data Method of Measuring Water Level				
_ • .	Circle one			
Date Well Tested: //- // - 0 4				
Static Water Level (A): 45 Feet Below Land Surface	Air Line Electric Measuring Line Steel Tape			
Pumping Water Level (B): 56 Feet Below Land Surface	Other (specify):			
Drawdown [(B) – (A)]:Feet Below Land Surface	For flowing well, measured shut in head:feet			
Test Pumping Rate:33Gallons Per Minute	Well yieldedGPM with a drawdown of			
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping			
I HEREBY CERTIFY that the above statements are true to the best of my knowledge?				

Signature of Pump Installer

BY: OLWR