

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED LEAKE	WELL NUMBER M 2032	CODED 6-15-1990	PERMIT NUMBER F.O. Cannon
DATE WELL COMPLETED			NAME OF DRILLING FIRM

NAME & MAILING ADDRESS OF LANDOWNER
Frank R. Palmer
RT 3
Corthong Mia

WELL LOCATION: SEC **27** TOWNSHIP **10th S** RANGE **9th W**

DISTANCE **2** Miles **N** DIRECTION of **MADDELYN** NEAREST TOWN

OTHER LANDMARK
HOME

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P **LH**

Pump Capacity (GPM) 372	No. of Stages	Setting Depth 100' FT.
-----------------------------------	---------------	----------------------------------

PUMP TEST

Well yielded _____ GPM with
a drawdown of **10'** ft.
after **60'** hours of pumping

WELL DATA

Well Depth 210'	Casing Diameter (In.) 2"	Casing Length (Ft.) 120'
Type of Casing pvc	Hole Depth 35'	Depth to Static Water Level 40'

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other

Top of Lap Pipe or Reduction in Casing
2 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) **NO**

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches 2"	Length - Feet 120'	Slot Size - Inches
Screen Type	Depth to Bottom - Feet 210'	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATION
Red	0'	40'	
fine sand	40'	60'	
light beach	60'	140'	
green and Rock	140'	210'	

RECEIVED

MAY 17 1990

Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK