

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

21

COUNTY WELL LOCATED
LEE

WELL NUMBER
B-15

CODED

DATE WELL COMPLETED
MAY 2004

PERMIT NUMBER

NAME OF DRILLING FIRM
LEE PETER DRILLING

FOR TSTC

NAME & MAILING ADDRESS OF LANDOWNER
Hancock Fabrics
Baldwyn, MS

Latitude:
Longitude:

WELL LOCATION: SEC 10 TOWNSHIP 7 N RANGE 6 E

DISTANCE 1 Miles DIRECTION SW of NEAREST TOWN Baldwyn

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
IRRIGATION

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) 50 H/P

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>TOP CLAY</u>	<u>0</u>	<u>20</u>
<u>CHALK</u>	<u>20</u>	<u>100</u>
<u>Greenish Silty Clay</u>	<u>100</u>	<u>300</u>
<u>Silty Green Sand</u>	<u>300</u>	<u>350</u>
<u>EUTAW</u>	<u>350</u>	<u>440</u>

WELL DATA

Well Depth <u>440</u>	Casing Diameter (In.) <u>4"</u>	Casing Length (Ft.) <u>400</u>
Type of Casing <u>PVC</u>	Hole Depth <u>440</u>	Depth to Static Water Level <u>90</u>

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <u>4"</u>	Length - Feet <u>40</u>	Slot Size - Inches <u>.010</u>
Screen Type <u>Slot + PVC</u>	Depth to Bottom - Feet <u>440</u>	

RECEIVED

JUN 23 2004

BY: OLWR

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

[Signature]
Signature of Licensed Driller and License No.

6-28-04
Date

Additional Information Required On Back