

81

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631  
Jackson, MS 39289-0631  
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED  
**LEE**

WELL NUMBER  
**Q 119**

PERMIT NUMBER

DATE WELL COMPLETED  
**JAN 2004**

NAME OF DRILLING FIRM  
**LEAPER Drilling**

**PONTIAC**

NAME & MAILING ADDRESS OF LANDOWNER  
**DARRELL CLOCK**  
**Clock Drive**  
**Shannon, MS**

Latitude:

Longitude:

WELL LOCATION SEC TOWNSHIP RANGE  
**20 11 N 6 W**

DISTANCE DIRECTION NEAREST TOWN  
**2 Miles E of Shannon**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.  
**Home**

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) <b>20</b> H/P <b>1/2</b>		
DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<b>Top Clay</b>	<b>0</b>	<b>20</b>
<b>Blue Clay</b>	<b>20</b>	<b>80</b>
<b>Silt Greenish Clay</b>	<b>80</b>	<b>350</b>
<b>Silty Sand</b>	<b>350</b>	<b>400</b>
<b>ELITAW</b>	<b>400</b>	<b>460</b>

WELL DATA

Well Depth <b>460</b>	Casing Diameter (In.) <b>4"</b>	Casing Length (Ft.) <b>420</b>
Type of Casing <b>Pk</b>	Hole Depth <b>460</b>	Depth to Static Water Level <b>93</b>

TYPE OF COMPLETION: (Circle One or More):  
Gravel Packed, Underreamed, Telescoped,  
Natural Development, Open Hole, Other  
(Describe)

WELL GROUTED TO A DEPTH OF **10 FEET**  
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - inches <b>4"</b>	Length - Feet <b>40</b>	Slot Size - inches <b>.010</b>
Screen Type <b>Slotted Pk</b>	Depth to Bottom - Feet <b>460</b>	

RECEIVED  
JUN 30 2004  
BY: OLWR

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

*[Signature]*  
Signature of Licensed Driller and License No.

**6-28-04**  
Date

Additional Information Required On Back