

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED LeFlore	
WELL NUMBER E-2010	CODED
DATE WELL COMPLETED 8-6-99	

PERMIT NUMBER
NAME OF DRILLING FIRM IRRIGATION EQUIPMENT
601/881-2555
OSHTMOGA, MS

NAME & MAILING ADDRESS OF LANDOWNER Backwater Brake Timber Co.		
Box 551		
Greenwood, MS 38930		
WELL LOCATION: SEC	TOWNSHIP	RANGE
sw/nw	19 21	(N) 1 (E)
DISTANCE	DIRECTION	NEAREST TOWN
6 Miles	NE	money
OTHER LANDMARK		
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.		

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine Jet Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric, Tractor, Diesel , Gasoline, Butane, Other (Describe) H/P 40		
Pump Capacity (GPM) 2000	No. of Stages 1	Setting Depth 60 FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 111	Casing Diameter (In.) 16	Casing Length (Ft.) 91
Type of Casing PVC	Hole Depth 111	Depth to Static Water Level 12 Ft.
TYPE OF COMPLETION: (Circle One or More): Gravel Packed Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	


WELL GROUTED TO A DEPTH OF _____ FEET Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 16	Length - Feet 20	Slot Size - Inches .050
Screen Type PVC	Depth to Bottom - Feet 111	

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
CLAY	0	21
FINE SAND + CLAY	21	91
med. SAND + Gravel	91	111

FORMATIONS ENCOUNTERED	FROM	TO
CLAY	0	21
FINE SAND + CLAY	21	91
med. SAND + Gravel	91	111
OCT 08 1999		
		
Dept. of Environmental Quality Office of Land & Water Resources		
IF MORE SPACE IS NEEDED, USE BACK:		

