County:	Leflore	
Permit #:	GW-46001 04-	
Driller:	Irrigation Equipment	
Date drilling completed: 06/21/2012		

State Well Report Part 1 – Driller's Log Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 2309 Jackson, MS 39225 (601) 961-5210 (601) 961-5228 (fax)

For Office Use Only:			
Aquifer:	P 172		
Well #:	<u></u>		
L.S. Elevation:			
E-log #:			

State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.

Information on Well Owner		Well or Borehole Location
(Landowner if borehole is not for a water well)		19 08 44
Owner Name D Row	land Farms	Latitude: <u>33</u> ° <u>18</u> ' <u>26</u> " Longitude: <u>90</u> ° <u>23</u> ' <u>51</u> '
Mailing Address: 104 Fra	anklin Street	_ Method of Lat/Long (check one):
		USGS quad, 🛛 Hand-held GPS, 🗌 Survey-grade GPS
Isola	Ms 38754	
City	State Zip code	Distance Direction Nearest Town
Telephone No. ())	Miles of Swiftown
	Well /	Borehole Data
Date drilling started:	Date drilling completed: _0	6/21/2012 Hole depth: 125 Hole diameter: 24"
Location of the source of an	y surface water used for drilling: Surfa	ce Water
	ne of Chlorine used in drilling and develop	
Logs run (check all applicab Name of organization running		ma Ray Density Sonic Neutron Other:
Purpose of borehole (check	one): 🛛 Water Well 🗌 Geotechni	cal/Geological Investigation 🔲 Ground Source Heat Pump
	Seismic Survey Othe	r (describe)
If drilling is not related to water well construction, skip the remainder of this block		
Purpose of Well (check one) Home Industrial Public Supply Irrigation Fish Culture Other:		
		describe)
Static Water Level: 15 feet above or below (check one) 🗌 land 🛛 surface Date measured: 06/21/2012		
Method of Measurement (check one) 🛛 steel tape 🗌 electric tape 🔲 air line 🔲 other:		
Well depth: 125 Well grouted to a depth of 10 feet Type of grout (check one): Neat Cement Bentonite Mix		
Casing length: 85 feet Casing diameter: 16 inches Type of casing: PVC		
Screen length: 40 feet Screen diameter: 16 inches Type of screen: PVC		
Screen slot size: .050	inches Setting depth: From	m <u>86</u> feet to <u>125</u> feet
Type of completion (check all applicable): 🛛 Gravel packed 🔲 Underreamed 🗍 Telescoped 🗌 Open hole 🗌 Natural Development		
	Other (describe):	
Top of lap pipe or reduction in casing: feet. If telescoped or more than one screen, describe on next page		
		Form: OLWR-SWR-1A (04/08)

The sketch below only required for water wells

If well telescopes, show depths on sketch.

Ground level

1

Description of formations encountered must be provided for all wells and boreholes, unless specifically exempted by regulations

172

Description of Formations Encountered	From (depth)	
Clay	Ground level	35
Fine Sand	36	45
Medium Sand	46	65
Course Sand & Gravel	66	125
· · · · · · · · · · · · · · · · · · ·		
		ļ
· · · · · · · · · · · · · · · · · · ·		

If more than one screen, show location of each on sketch

Sketch the property layout and include the fo aid in locating the well; 3) and 4) a north arrow.		n; 2) any permanent structures on er items that may aid in locating t	
,			
Landowner Name: D Rowland Farms			
		· · · · · · · · · · · · · · · · · · ·	Form: OLWR-SWR-1A (04/08)
I certify that the well/borehole was drilled, constr Mississippi Department of Equipermental Quality	ructed, and completed in according to the Mississiani Department	ordance with all applicable require	ments of the
Mississippi Department of Environmental Qualit laws.	y and the mississippi Depart	ment of Health regulations, if appli	cable, and state
Patrick Chism 0695	07/17/2012		and them by the fame of the second
Print Name of Responsible Licensee and License No.	Date	Signature of Licensee	have been been been

 07/17/2012	
Date	

JUL 1 9 2012

STATE WELL REPORT

County:	Leflore		
Permit #:	GW-46001- 04-:		
Driller:	Irrigation Equipment		
Date drilling completed: 06/21/2012			
Copy information from block on Part 1			

,

Part 2 Pump Installer's Completion Report

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 2309 Jackson, MS 39225 (601) 961-5210 (601) 961-5228 (fax)

For Office Use Only:		
Aquifer:		
Well #:		
Elevation:		

This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.

Well Owner Information	Vell Location 44	
Owner Name: D.Rowland Farms	Latitude: 33 18' 26.4 N Longitude: 90 23' 51.1 W	
Mailing Address: 104 Franklin Street	Method of Lat/Long (check one):	
	USGS quad, X Hand-held GPS, Survey-grade GPS	
Isola Ms 38754	<u>SHE ¼ SW ¼ Sec 22</u> T <u>17N</u> R <u>2W</u>	
City State Zip code	Distance Direction Nearest Town	
Telephone No	<u>1</u> Miles <u>East</u> of <u>Swiftown</u>	
Pump Type Check one	Power Type Check one	
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas	
Bucket Piston I Turbine	Electric Motor Hand Tractor PTO	
Centrifugal Rotary Flowing Well	Windmill Other (specify):	
Other (specify):	Horse Power Rating of Motor: 60	
Date Pump Installed: 06/21/2012	Setting Depth: 70 feet	
Rated Pump Capacity 2500+/- Gallons Per Minute	Number of Stages: 1	
Pump Test Data	Method of Measuring Water Level Check one	
Date Well Tested:	Air Line Electric Measuring Line Steel Tape	
Static Water Level (A): Feet Below Land Surface	Other (specify):	
Pumping Water Level (B): Feet Below Land Surface		
Drawdown [(B) - (A)]: Feet Below Land Surface	For flowing well, measured shut in head: feet	
Test Pumping Rate: Gallons Per Minute	Well yielded GPM with a drawdown of	
Duration of Pump Test (minimum 4 hours): hours	feet after hours of pumping	
This is for (check one): New Well Replacement of Existing Pump Repair of Existing Pump		
I HEREBY CERTIFY that the above statements are true to the best of my knowledge.		
Patrick Chism 0695 Cut DECENCE		
Print Name of Pump Installer and License No. (if applicable)	Signature of Pump Installer	
	Form: Of WR-Styre 10(01/09)	