

4/13/00

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Lincoln

WELL NUMBER
L-2211

CODED

DATE WELL COMPLETED
4-20-00

PERMIT NUMBER
Green Water Well & Supply

NAME OF DRILLING FIRM
1318 Pricedale Dr. SE
Bogue Chitto, MS 39629

NAME & MAILING ADDRESS OF LANDOWNER
Greg McCaffery
0422 McCaffery Rd.
Bogue Chitto

WELL LOCATION: SEC 28 TOWNSHIP 6 RANGE 7
N S W E

DISTANCE 2 1/2 Miles DIRECTION NW of Bogue Chitto

OTHER LANDMARK

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P 1/2

Pump Capacity (GPM) 10 No. of Stages 9 Setting Depth 95 FT.

PUMP TEST

Well yielded 10 GPM with
a drawdown of 0 ft.
after 1 hours of pumping

WELL DATA

Well Depth 110' Casing Diameter (In.) 4" Casing Length (Ft.) 100'

Type of Casing PVC Hole Depth 119' Depth to Static Water Level 64'

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run
 Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches 4 Length - Feet 10 Slot Size - Inches .010

Screen Type PVC Depth to Bottom - Feet 110

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Red Clay	0	20			
Sand & Gravel	20	80			
Sand w/ Clay streaks	80	96			
Sand	96	110			
Yellow Clay	110	119			

IF MORE SPACE IS NEEDED, USE BACK

