

Part 2 never received 4/13

State Well Report

Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:

Aquifer: _____
Well #: R-42
L. S. Elevation: _____
E-log #: _____

County: Lincoln
Permit #: _____
Driller: GRENN WATER WELL & SUPPLY, INC.
Date drilling completed: 6/29/05

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	Well Location
Owner Name: <u>Pete Reid</u>	Latitude: <u>31° 23' 00⁴¹</u> Longitude: <u>90° 16' 30²²</u>
Mailing Address: <u>3629 Primitive Dr SE</u>	Method of Lat/Long (circle one): <input checked="" type="checkbox"/> Conventional Survey
<u>Ruth</u> <u>MS</u> <u>39662</u>	USGS quad, <input checked="" type="checkbox"/> Hand-held GPS <input type="checkbox"/> Survey-grade GPS
City State Zip Code	<u>SE 1/4 SW 1/4</u> Sec <u>14</u> Twn <u>5N</u> Rng <u>9E</u>
Telephone No. <u>601 734-2623</u>	Distance Direction Nearest Town <u>2.5</u> Miles <u>E</u> of <u>Ruth</u>

Well Data

Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: _____

Date well drilling started: 6/29/05 Date well drilling completed: 6/29/05

If flowing, method of flow regulation: Valve _____ Other (describe) _____

Static Water Level: 65 feet above or below (circle one) land surface Date measured: 6/29/05

Method of Measurement (circle one) steel tape electric tape air line other: _____

Hole depth: 164 Well depth: 157 Well grouted to a depth of 10 feet

Type of grout (circle one): Cement Bentonite Mix

Casing length: 147 feet Casing diameter: 4 inches Type of casing: PVC

Screen length: 10 feet Screen diameter: 4 inches Type of screen: PVC

Screen slot size: .010 inches Setting depth: From 147 feet to 157 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development
Other (describe): _____

Top of lap pipe or reduction in casing: _____ feet. If telescoped or more than one screen, describe on back of page

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: _____

Name of organization running log(s): _____

I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

GRENN WATER WELL & SUPPLY, INC.
Brian McClendon, lic. no. 0-664

Brian McClendon

Print Name of Water Well Contractor and License No.

Signature of Water Well Contractor

RECEIVED

JUL 23 2005
BY: OLWR

