

# State Well Report

## Part 1

Mississippi Department of Environmental Quality  
Office of Land and Water Resources  
P.O. Box 10631  
Jackson, MS 39289-0631  
(601)961-5210  
(601)354-6938 (fax)

For Office Use Only:

Aquifer: \_\_\_\_\_  
Well #: C-57  
L. S. Elevation: \_\_\_\_\_  
E-log #: \_\_\_\_\_

County: Marion  
Permit #: \_\_\_\_\_  
Driller: JAMES WELLS  
Date drilling completed: 1-17-08

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	Well Location
Owner Name: <u>Dewayne Stuckey</u>	Latitude: <u>31° 22' 25"</u> Longitude: <u>89° 49' 59"</u>
Mailing Address: <u>720 Stuckey Rd.</u>	Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS
<u>Columbia</u> MS <u>39429</u>	NE <u>1/4</u> NW <u>1/4</u> Sec. <u>32</u> Twn. <u>5N</u> Rng. <u>18W</u>
City State Zip Code	Distance Direction Nearest Town
Telephone No. ( ) _____	<u>6</u> Miles <u>N</u> of <u>Columbia</u>

**Well Data**

Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: \_\_\_\_\_

Date well drilling started: 1-17-08 Date well drilling completed: 1-17-08

If flowing, method of flow regulation: Valve \_\_\_\_\_ Other (describe) \_\_\_\_\_

Static Water Level: 100 feet above or below (circle one) land surface Date measured: 1-17-08

Method of Measurement (circle one) steel tape electric tape air line other: \_\_\_\_\_

Hole depth: 250 Well depth: 250 Well grouted to a depth of 10 feet

Type of grout (circle one): Cement Bentonite Mix

Casing length: 230 feet Casing diameter: 4 inches Type of casing: PVC

Screen length: 20 feet Screen diameter: 4 inches Type of screen: PVC

Screen slot size: 008 inches Setting depth: From 230 feet to 250 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development

Other (describe): \_\_\_\_\_

Top of lap pipe or reduction in casing: \_\_\_\_\_ feet. If telescoped or more than one screen, describe on back of page

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: \_\_\_\_\_

Name of organization running log(s): \_\_\_\_\_

I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

JAMES WELLS 0-586  
Print Name of Water Well Contractor and License No.

James Wells  
Signature of Water Well Contractor

RECEIVED

FEB 07 2008

BY: OLWR



# STATE WELL REPORT

## Part 2

Pump Installer's Completion Report  
Mississippi Department of Environmental Quality  
Office of Land and Water Resources  
P.O. Box 10631  
Jackson, MS 39289-0631  
(601)961-5210  
(601)354-6938 (fax)

For Office Use Only:

Aquifer: \_\_\_\_\_

Well #: C-57

Elevation: \_\_\_\_\_

County: Marion

Permit #: \_\_\_\_\_

Driller: JAMES WELLS

Date completed: 1-17-08

This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump.

### Well Owner Information

Owner Name: Dwayne Stuckey

Mailing Address: 720 Stuckey Rd.

Columbia MS 39429  
City State Zip Code

Telephone No. ( ) \_\_\_\_\_

### Well Location

Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_

Method of Lat/Long (circle one): Conventional Survey,

USGS quad, Hand-held GPS, Survey-grade GPS

1/4 1/4 Sec. 32 Twn 5N Rng 18W

Distance Direction Nearest Town

6 Miles N of Columbia

### Pump Type Circle one

Air Lift Jet Submersible

Bucket Piston Turbine

Centrifugal Rotary Flowing Well

Other (specify): \_\_\_\_\_

Date Pump Installed: 1-17-08

Rated Pump Capacity: 20 Gallons Per Minute

### Power Type Circle one

Diesel Engine Gasoline Engine Natural Gas

Electric Motor Hand Tractor PTO

Windmill Other (specify): \_\_\_\_\_

Horse Power Rating of Motor: 1 1/2

Setting Depth: 150 feet

Number of Stages: 12

### Pump Test Data

Date Well Tested: 1-17-08

Static Water Level (A): 100 Feet Below Land Surface

Pumping Water Level (B): 150 Feet Below Land Surface

Drawdown [(B) - (A)]: 110 Feet Below Land Surface

Test Pumping Rate: 22 Gallons Per Minute

Duration of Pump Test (minimum 4 hours): 4 hours

### Method of Measuring Water Level Circle one

Air Line Electric Measuring Line Steel Tape

Other (specify): \_\_\_\_\_

For flowing well, measured shut in head: \_\_\_\_\_ feet

Well yielded 22 GPM with a drawdown of

10 feet after 4 hours of pumping

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

JAMES WELLS 0-586  
Print Name of Pump Installer and License No. (if applicable)

James Wells  
Signature of Pump Installer

RECEIVED

FEB 07 2008

BY: OLWR