County: Marion
Permit #:
Driller JAMES WELLS
Date drilling completed: 7-28-06

Print Name of Water Well Contractor and License No.

## State Well Report

## Part 1

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

For Office Use On	ly:
Aquifer:	-
Well #:	105
E-log #:	

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well. Well Location Well Owner Information 15 " Longitude: 89.51.56" Latitude: 31 Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS Zip Code City Direction Nearest Town Distance Telephone No. (504 366-561) Well Data Fish Culture Irrigation **Public Supply** Purpose of Well (circle one) Home Industrial Date well drilling completed: 7-28-06 Date well drilling started: 7-28-06 Other (describe) If flowing, method of flow regulation: Valve\_ Date measured: feet above or below (circle one) land surface air line electric tape Steel tape) Method of Measurement (circle one) Well grouted to a depth of Well depth: Hole depth: Bentonite Mix Type of grout (circle one): Cement Type of casing: inches Casing diameter: Casing length: Type of screen: Screen diameter: Screen length: feet feet to Setting depth: From Natural Development Open hole Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Other (describe): feet. If telescoped or more than one screen, describe on back of page Top of lap pipe or reduction in casing: Logs run (circle all applicable) No log run Electric Gamma Ray Density Sonic Neutron Other: Name of organization running log(s): I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws. Signature of Water Well Contractor

AUG 1 0 2006

BY: OLWR

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property as aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property as	d the well;
4) indicate direction.	-

LANDOWNER NAME PR RUSSELL Dimor CO

Signature of Water Well Contractor

**RECEIVED** 

AUG 1 0 2006

BY: OLWR

## STATE WELL REPORT

## Part 2

County: Marian Pump Installer's Completion Report

Mississippi Department of Environmental Quality

Office of Land and Water Resources

P.O. Box 10631

Jackson, MS 39289-0631

(601)961-5210

(601)354-6938 (fax)

For Office Use Only:		
Aquifer:	K105_	
Well#:	× 132	
Elevation:		

This report should be prepared by the pump installer in detail	and filed with the Department within 30 days of the	
المنافعة المالية المال	Well Location	
Well Owner Information	AACM TVACTORIA	
Owner Name: DR. Russell Dimar Co	Latitude: Longitude:	
Mailing Address: 299 010 Foxworth Jamestow	(Method of Lat/Long (circle one): Conventional Survey.	
Foxworth, M5 39483	USGS quad, Hand-held GPS, Survey-grade GPS	
City State Zip Code	SE 14 SW 14 Sec 33 Twn 3E Rng 3  Distance Direction Nearest Town	
Telephone No. 504 366 - 5611		
	Power Type	
Pump Type Circle one	Circle one	
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas  Hand Tractor PTO	
Bucket Piston Turbine	Place value	
Centrifugal Rotary Flowing Well		
Other (specify):	Horse Power Rating of Motor: 1/3	
Date Pump Installed: 7-28-06	Setting Depth:feet	
Rated Pump Capacity: Gallons Per Minute	Number of Stages:	
	Method of Measuring Water Level	
Pennep Test Data	Circle one	
Date Well Tested: 7-28-06	Air Line Electric Measuring Line Steel Tape	
Static Water Level (A): 20 Peet Below Land Surface	Other (specify):	
Pumping Water Level (B): 40 Feet Below Land Surface		
Drawdown [(B) – (A)]: JO Feet Below Land Surface	For flowing well, measured shut in head:feet	
Test Pumping Rate: 25 Gallons Per Minute	Well yielded 25 GPM with a drawdown of	
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping	
L		
I HEREBY CERTIFY that the above statements are true to the best of my knowledge.		
JAMES WELLS 0-586	Signature of Pump Installer	
Print Name of Pump Installer and License No. (if applicable)		

**RECEIVED** 

AUG 1 0 2006

BY: OLWR