

County: Marshall  
 Permit #: \_\_\_\_\_  
 Driller: Jones W. Masew  
 Date drilling completed: 5-12-06

### State Well Report Part 1 - Driller's Log

Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 10631  
 Jackson, MS 39289-0631  
 (601)961-5210  
 (601)354-6938 (fax)

**For Office Use Only:**  
 Aquifer: \_\_\_\_\_  
 Well #: D-105  
 L. S. Elevation: \_\_\_\_\_  
 E-log #: \_\_\_\_\_

*State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.*

| Information on Well Owner<br>(Landowner if borehole is not for a water well) | Well or Borehole Location  |
|--|--|
| Owner Name: <u>Bill Rowe</u>   | Latitude: <u>34° 56' 08"</u> Longitude: <u>89° 40' 26"</u>                           |
| Mailing Address: <u>LOT 4</u>  | Method of Lat/Long (circle one): Conventional Survey, <u>OS</u>                      |
| <u>deercreek rd.</u>   | USGS quad, <u>Hand-held GPS</u> Survey-grade GPS <input checked="" type="checkbox"/> |
| <u>Byholia MS 38611</u>  | <u>SE</u> 1/4 <u>SW</u> 1/4 Sec <u>1</u> Twn <u>25</u> Rng <u>5W</u>                 |
| City State Zip Code  | Distance <u>1 7/8</u> Miles Direction <u>SE</u> of Nearest Town <u>Barton</u>        |
| Telephone No. <u>(662) 895-8556</u>  |  |

**Well / Borehole Data**

Date drilling started: 5-12-06 Date drilling completed: 5-12-06 Hole depth: 110 Hole diameter: 6 3/4

Location of the source of any surface water used for drilling: NA

Method of dosing and volume of Chlorine used in drilling and development: NA

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: \_\_\_\_\_

Name of organization running log(s): NA

Purpose of borehole (check one): Water Well  Geotechnical/Geological Investigation \_\_\_\_\_ Ground Source Heat Pump \_\_\_\_\_

Seismic Survey \_\_\_\_\_ Other (describe) \_\_\_\_\_

*If drilling is not related to water well construction, skip the remainder of this block*

Purpose of Well (check one): Home  Industrial \_\_\_\_\_ Public Supply \_\_\_\_\_ Irrigation \_\_\_\_\_ Fish Culture \_\_\_\_\_ Other: \_\_\_\_\_

If a flowing well, method of flow regulation: Valve NA Other (describe) \_\_\_\_\_

Static Water Level: 15 feet above of below (circle one) land surface Date measured: 5-12-06

Method of Measurement (circle one) steel tape electric tape air line other: string weight

Well depth: 110 Well grouted to a depth of 10 feet Type of grout (circle one): Neat Cement Bentonite Mix

Casing length: 90 feet Casing diameter: 4 inches Type of casing: pvc

Screen length: 20 feet Screen diameter: 4 inches Type of screen: pvc

Screen slot size: 010 inches Setting depth: From 90 feet to 110 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development

Other (describe): NA

Top of lap pipe or reduction in casing: NA feet. *If telescoped or more than one screen, describe on next page*

Form: OLWR-SWR-1A

**RECEIVED**  
 JUN 12 2006  
 BY: OLWR



# STATE WELL REPORT

## Part 2

**Pump Installer's Completion Report**  
 Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 10631  
 Jackson, MS 39289-0631  
 (601)961-5210  
 (601)354-6938 (fax)

County: Marshall  
 Permit #: \_\_\_\_\_  
 Driller: Jones w. Masow  
 Date completed: 5-12-06  
*Copy information from block on Part 1*

**For Office Use Only:**

Aquifer: \_\_\_\_\_  
 Well #: D-105  
 Elevation: \_\_\_\_\_

*This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.*

| Well Owner Information                                 | Well Location  |
|--|--|
| Owner Name: <u>Bill Rowe</u>                           | Latitude: <u>34.56.088</u> Longitude: <u>89.40.764</u>   |
| Mailing Address: <u>LOT 4</u><br><u>cleercreek rd.</u> | Method of Lat/Long (check one): Conventional Survey _____<br>USGS quad _____, Hand-held GPS <input checked="" type="checkbox"/> , Survey-grade GPS _____ |
| <u>Byholia MS 38611</u><br>City State Zip Code         | <u>SE 1/4 SW 1/4 Sec 1 T25 R 5w</u>  |
| Telephone No. <u>(662) 895-8556</u>                    | Distance Direction Nearest Town<br><u>1 7/8 Miles SE of Barton</u>   |

| Pump Type<br>Circle one  | Power Type<br>Circle one   |
|--|--|
| Air Lift Jet <input type="checkbox"/> <b>Submersible</b> <input checked="" type="checkbox"/> | Diesel Engine Gasoline Engine Natural Gas  |
| Bucket Piston <input type="checkbox"/> Turbine <input type="checkbox"/>                      | <b>Electric Motor</b> <input checked="" type="checkbox"/> Hand <input type="checkbox"/> Tractor PTO <input type="checkbox"/> |
| Centrifugal Rotary <input type="checkbox"/> Flowing Well <input type="checkbox"/>            | Windmill Other (specify): _____  |
| Other (specify): _____   | Horse Power Rating of Motor: <u>1 1/2</u>  |
| Date Pump Installed: <u>5-12-06</u>  | Setting Depth: <u>60</u> feet  |
| Rated Pump Capacity: <u>20</u> Gallons Per Minute  | Number of Stages: <u>14</u>  |

| Pump Test Data   | Method of Measuring Water Level<br>Circle one           |
|--|---|
| Date Well Tested: <u>5-12-06</u>                           | Air Line Electric Measuring Line Steel Tape             |
| Static Water Level (A): <u>15</u> Feet Below Land Surface  | Other (specify): <u>string / weight</u>                 |
| Pumping Water Level (B): <u>NA</u> Feet Below Land Surface | For flowing well, measured shut in head: <u>NA</u> feet |
| Drawdown [(B) - (A)]: <u>NA</u> Feet Below Land Surface    | Well yielded <u>20</u> GPM with a drawdown of           |
| Test Pumping Rate: <u>20</u> Gallons Per Minute            | <u>NA</u> feet after <u>24</u> hours of pumping         |
| Duration of Pump Test (minimum 4 hours): <u>24</u> hours   |   |

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

Jones w. Masow Print Name of Pump Installer and License No. (if applicable)      Jones w. Masow Signature of Pump Installer

Form: OLWR-SWR-1B

**RECEIVED**  
 JUN 12 2006  
 BY: OLWR