

# State Well Report

## Part 1 - Driller's Log

Mississippi Department of Environmental Quality  
Office of Land and Water Resources  
P.O. Box 10631  
Jackson, MS 39289-0631  
(601)961-5210  
(601)354-6938 (fax)

### For Office Use Only:

Aquifer: \_\_\_\_\_  
Well #: E-195  
L. S. Elevation: \_\_\_\_\_  
E-log #: \_\_\_\_\_

County: Marshall  
Permit #: 0-162  
Driller: Larry Carpenter  
Date drilling completed: 9-28-07

**State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.**

| Information on Well Owner<br>(Landowner if borehole is not for a water well) | Well or Borehole Location   |
|--|---|
| Owner Name: <u>Anderson Home LLC</u>   | Latitude: <u>34° 52' 29"</u> Longitude: <u>89° 31' 07"</u>  |
| Mailing Address: <u>P.O. Box 539</u>   | Method of Lat/Long (circle one): Conventional Survey,<br>USGS quad, Hand-held GPS, Survey-grade GPS |
| <u>Holly Springs</u> <u>Ms.</u> <u>38635</u><br>City State Zip Code          | <u>NE 1/4 NE 1/4 Sec 36</u> Twn <u>25</u> Rng <u>4W</u>   |
| Telephone No. <u>(662) 252-3500</u>  | Distance <u>2 1/2</u> Miles Direction <u>South</u> of <u>Pal Rankin</u>                             |

### Well / Borehole Data

Date drilling started: 9-28-07 Date drilling completed: 9-28-07 Hole depth: 125' Hole diameter: 8"  
Location of the source of any surface water used for drilling: Well Water  
Method of dosing and volume of Chlorine used in drilling and development: 1/2 Pk Chlorine to 1000 Gal. Water  
Logs run (circle all applicable):  No log run  Electric  Gamma Ray  Density  Sonic  Neutron  Other: \_\_\_\_\_  
Name of organization running log(s): \_\_\_\_\_  
Purpose of borehole (check one): Water Well  Geotechnical/Geological Investigation \_\_\_\_\_ Ground Source Heat Pump \_\_\_\_\_  
Seismic Survey \_\_\_\_\_ Other (describe) \_\_\_\_\_  
**If drilling is not related to water well construction, skip the remainder of this block**

Purpose of Well (check one): Home  Industrial \_\_\_\_\_ Public Supply \_\_\_\_\_ Irrigation \_\_\_\_\_ Fish Culture \_\_\_\_\_ Other: \_\_\_\_\_  
If a flowing well, method of flow regulation: Valve \_\_\_\_\_ Other (describe) \_\_\_\_\_  
Static Water Level: 75 feet above or  below (circle one) land surface Date measured: 9-28-07  
Method of Measurement (circle one)  steel tape  electric tape  air line  other: \_\_\_\_\_  
Well depth: 125' Well grouted to a depth of 10 feet Type of grout (circle one):  Neat Cement  Bentonite  Mix  
Casing length: 115 feet Casing diameter: 4 inches Type of casing: PVC  
Screen length: 10 feet Screen diameter: 4 inches Type of screen: PVC  
Screen slot size: .013 inches Setting depth: From 115 feet to 125 feet  
Type of completion (circle all applicable):  Gravel packed  Underreamed  Telescoped  Open hole  Natural Development  
Other (describe): \_\_\_\_\_  
Top of lap pipe or reduction in casing: \_\_\_\_\_ feet. **If telescoped or more than one screen, describe on next page**

RECEIVED  
Form: OLWR-SWR-1A

OCT 28 2007  
BY: OLWR

E-195

The sketch below only required for water wells

Description of formations encountered must be provided for all wells and boreholes, unless specifically exempted by regulations

If well telescopes, show depths on sketch.

Ground Level  $\rightarrow$

| Description of Formations Encountered | From (depth) | To (depth) |
|---------------------------------------|--------------|------------|
|                                       | Ground Level |            |
| Surface Soil                          | 0            | 18         |
| Red Red Sand                          | 18           | 40         |
| Fine White Sand                       | 40           | 70         |
| White clay                            | 70           | 94         |
| Coarse White Sand                     | 94           | 125        |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |
|                                       |              |            |

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; 4) a north arrow.

Property

Driveway

Well

House

North

North Red Banks Rd.

Landowner Name: Anderson Homes

Form: OLWR-SWR-1A

I certify that the well/borehole was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and the Mississippi Department of Health regulations, if applicable, and state laws.

LARRY CARPENTER 0-112      10-5-07

Larry Carpenter **RECEIVED**

Print Name of Responsible Licensee and License No.

Date

Signature of Licensee

OCT 26 2007

BY: OLWR

# STATE WELL REPORT

## Part 2

**Pump Installer's Completion Report**  
 Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 10631  
 Jackson, MS 39289-0631  
 (601)961-5210  
 (601)354-6938 (fax)

**For Office Use Only:**

Aquifer: \_\_\_\_\_  
 Well #: E-195  
 Elevation: \_\_\_\_\_

County: Marshall  
 Permit #: 0-162  
 Driller: Larry Carpenter  
 Date completed: 9-28-07  
Copy information from block on Part 1

*This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.*

| Well Owner Information   | Well Location   |
|--|---|
| Owner Name: <u>Anderson Horner</u>                                 | Latitude: _____ Longitude: _____  |
| Mailing Address: <u>P. O. Box 539</u>                              | Method of Lat/Long (check one): Conventional Survey _____<br>USGS quad _____, Hand-held GPS _____, Survey-grade GPS _____ |
| <u>Holly Springs</u> <u>Ms</u> <u>38635</u><br>City State Zip Code | <u>1/4</u> <u>1/4</u> Sec <u>36</u> T <u>25</u> R <u>4W</u>   |
| Telephone No. <u>(662) 252-3500</u>                                | Distance Direction Nearest Town<br><u>2 1/2</u> Miles <u>North</u> of <u>Red Bank</u>                                     |

| Pump Type<br>Circle one  | Power Type<br>Circle one  |
|--|---|
| Air Lift Jet <input type="radio"/> <input checked="" type="radio"/> <u>Submersible</u> | Diesel Engine Gasoline Engine Natural Gas                               |
| Bucket Piston Turbine  | <input checked="" type="radio"/> <u>Electric Motor</u> Hand Tractor PTO |
| Centrifugal Rotary Flowing Well  | Windmill Other (specify): _____   |
| Other (specify): _____   | Horse Power Rating of Motor: <u>3/4</u>                                 |
| Date Pump Installed: <u>9-28-07</u>  | Setting Depth: <u>100</u> feet  |
| Rated Pump Capacity: <u>10</u> Gallons Per Minute                                      | Number of Stages: <u>11</u>   |

| Pump Test Data   | Method of Measuring Water Level<br>Circle one                                       |
|--|---|
| Date Well Tested: <u>9-28-07</u>                           | Air Line Electric Measuring Line <input checked="" type="radio"/> <u>Steel Tape</u> |
| Static Water Level (A): <u>75</u> Feet Below Land Surface  | Other (specify): _____  |
| Pumping Water Level (B): <u>80</u> Feet Below Land Surface | For flowing well, measured shut in head: _____ feet                                 |
| Drawdown [(B) - (A)]: <u>5</u> Feet Below Land Surface     | Well yielded <u>16</u> GPM with a drawdown of                                       |
| Test Pumping Rate: <u>16</u> Gallons Per Minute            | <u>5</u> feet after <u>4</u> hours of pumping                                       |
| Duration of Pump Test (minimum 4 hours): <u>4</u> hours    |   |

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

LARRY CARPENTER 0-162  
 Print Name of Pump Installer and License No. (if applicable)

Larry Carpenter OCT 28 2007  
 Signature of Pump Installer

**RECEIVED**  
**BY: OLIVE**  
 Form: OLWR-SWR-1B