County: Marshall
Permit #:
Driller: Jones W. Moson.
Date drilling completed: <u>2-6-07</u>

## **State Well Report**

Part 1 - Driller's Log

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:
Aquifer:
Well #:
L. S. Elevation:
E-log #:

State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.

Department at the above address within 30 days of comp	neuton of unuing of the well of borenote.
Information on Well Owner	Well or Borehole Location
(Landowner if borehole is not for a water well)	
(Danaonner if borenote is not for a water wear)	Latitude 34 · 42 · 366 " Longitude: 89 · 35 · 854
Owner Name Hous Sweet Holmes	Method of Lat/Long (circle one): Conventional Survey,
Mailing Address: COT (	Method of Lat/Long (circle one): Conventional Survey,
9	USGS quad, Hand-held GPS, Survey-grade GPS
Christiana (d	SW 1/4 New 1/4 Sec Twn 45 Rng W
Holly Springs Ms 38635 City Springs Ms Zip Code	74 19 - 74 Sec Will Kill Too
LOUR Springs WS	NW 2M
City State Zip Code	Distance Direction Nearest Town
	12 Miles S of Maricumag-
Telephone No. (901) 488-3397	
Well / Bore	hola Data
vven / Bore	noit Data
Date drilling started: $2-6-9$ Date drilling completed: $2-6-9$	Hole depth: 210' Hole diameter: 6314
Location of the source of any surface water used for drilling:	4
Method of dosing and volume of Chlorine used in drilling and devel	
Method of dosing and volume of Chlorine used in drilling and devel	opment: $\mathcal{N}^{\mathcal{T}}$
Logs run (circle all applicable): No log run Electric Gamma Ray	Density Sonic Neutron Other
Name of organization running log(s):	
Traine of organization running log(s).	<del></del>
Purpose of borehole (check one): Water Well Geotechnical/Geole	ogical Investigation Ground Source Heat Pump
Caiamia Cumun. Other (danset	<u>,                                     </u>
Seismic Survey Other ( <i>describe</i>	
If drilling is not related to water well construction	n, skip the remainder of this block
Purpose of Well (check one): Home <a href="Homogeneous Industrial">— Public Supply</a>	Laboritan Fish City on Others
Purpose of well (check one): Home $\nearrow$ industrial Public Supply	Irrigation Fish Culture Other:
If a flowing well, method of flow regulation: ValveO	ther (describe)
Static Water Level: 160 feet above or below scircle one) l	and surface Date measured: 3-10-07
Method of Measurement (circle one) steel tape electric tape	air line other: String lucignt
_	
Well depth: Well grouted to a depth of 10 feet Type	
Casing length: Accordance feet Casing diameter: 4	inches Type of casing:
Screen length: 10 feet Screen diameter: 4	inches Type of screen:
Screen slot size: Olo inches Setting depth: From	200 feet to 210 feet
Type of completion (circle all applicable): Gravel packed Under	reamed Telescoped Open hole Natural Development
Other (describe):	<u>, a</u>
Top of lap pipe or reduction in casing:	lescoped or more than one screen, describe on next page

Form: OLWR-SWR-1A

RECEIVED

FEB 2 6 2007

BY: OLWR

The	sketch	below	only	required	for	water	wells

## If well telescopes, show depths on sketch.

Ground Level.

## Description of formations encountered must be provided for all wells and boreholes, unless specifically exempted by regulations

Description of Formations Encountered	From (depth)	To (depth)
Clay dist.	Ground Level	40
red soud	40	65
white squal	65	90 _
white clay	90	140
white soud	140	210
		<del>                                     </del>
		<del>                                     </del>
		<del>                                     </del>
	1	1

If more than one screen, show location of each on sketch

aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well;
4) a north arrow.
Landowner Name: Homes Sweet Holmes

Form: OLWR-SWR-1A

I certify that the well/borehole was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and the Mississippi Department of Health regulations, if applicable, and state laws.

Times w. Moson 0-620 2-22-07

Print Name of Responsible Licensee and License No. Date

Signature of Licensee RECEIVED

FEB 26 2007

BY: OLWR

## STATE WELL REPORT Part 2 County: Marshall For Office Use Only: **Pump Installer's Completion Report** Mississippi Department of Environmental Quality Permit #: Aquifer: Office of Land and Water Resources P.O. Box 10631 Well #: Jackson, MS 39289-0631 Date completed: 3-10-07 (601)961-5210 Elevation: (601)354-6938 (fax) Copy information from block on Part 1 This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion. Well Location Well Owner Information Owner Name: Homes Sweet Holmes Latitude: 34-42.366 Longitude: 89.35. 854 Mailing Address: LOT USGS quad , Hand-held GPS\_\_\_\_\_\_, Survey-grade GPS\_\_\_\_\_\_\_ SW 1/ NW 1/ Sec 26 T 45 R 4W Distance Direction Nearest Town 1/2 Miles 5 of morianna Telephone No. (901) 488- 2237 **Pump Type** Power Type Circle one Circle one Air Lift Jet Submersible Diesel Engine Gasoline Engine Natural Gas Bucket Piston **Turbine** Electric Motor Hand **Tractor PTO** Centrifugal Rotary Flowing Well Windmill Other (specify): Horse Power Rating of Motor: 3/4 Other (specify): Date Pump Installed: 2-10-07 180 feet Setting Depth: 12 Rated Pump Capacity: Gallons Per Minute Number of Stages: Pump Test Data Method of Measuring Water Level Circle one Date Well Tested: 3 - 10 - 07Air Line Electric Measuring Line Steel Tape Static Water Level (A): 160 Feet Below Land Surface Other (specify): String I weight Pumping Water Level (B): A Feet Below Land Surface Drawdown [(B) - (A)]: \_\_\_ For flowing well, measured shut in head: feet Feet Below Land Surface 12 Test Pumping Rate: 12 GPM with a drawdown of Gallons Per Minute Well yielded feet after 34 hours of pumping Duration of Pump Test (minimum 4 hours): I HEREBY CERTIFY that the above statements are true to the best of my knowledge. Print Name of Pump Installer and License No. (if applicable) for w.Nlos bignature of Pump Installer

RECEIVED

FEB 2 6 2007

BY: OLWR