

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED MAKSHAH	
WELL NUMBER P 2106	CODED
DATE WELL COMPLETED 11-22-01	

PERMIT NUMBER
NAME OF DRILLING FIRM N. MS WELL DR
F. LANGFORD

NAME & MAILING ADDRESS OF LANDOWNER MARIE & ESTER TOLSTAIN			
1137 CAYCE RD			
Victoria MS			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	21	2	4
DISTANCE	DIRECTION	NEAREST TOWN	
4 Miles	N	of Victoria	
OTHER LANDMARK			
WELL PURPOSE <u>Home Irrigation</u> , Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P		
Pump Capacity (GPM)	No of Stages	Setting Depth
12		120 FT.
PUMP TEST		
Well yielded 15 GPM with a drawdown of 5 ft. after 3 hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In)	Casing Length (Ft)
170	4	20
Type of Casing	Hole Depth	Depth to Static Water Level
Pvc	170	50' F. TOP
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)		
WELL GROUTED TO A DEPTH OF _____ FEET Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma-Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	
No Log Run	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
4	10	.013
Screen Type	Depth to Bottom - Feet	

GEOLOGIC DATA (Office Use Only)			
Surface Elev	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
DIRT	0	10			
Red SAND	10	30	2 Mobil Homes		
SAND	30	60			
w/clay	60	70	Hooked UP JUN 11, 2001		
mixed c / SAND	70	110	This well		
w / SAND	110	170	plenty water		
			IF MORE SPACE IS NEEDED, USE BACK		

