

ELOG #53

OKTIBBEHA  
G33  
12-70

MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201  
WATER WELL DRILLERS LOG

**CODED**

December 19 70 Carloss Well Supply Co. Oktibbeha  
date well completed firm name county well located

LANDOWNER:  
Mississippi State University  
State College, Mississippi  
(mailing address)

description of formations encountered from to  
Hard Soapstone 200'  
Hard Shale 690'

WELL LOCATION:  
sec. 1 T. 18 N. R. 14 E  
2 miles East of Starkville  
(distance) (direction) of (nearest town)

Sand 720'  
Sandy Shale 865'  
Fine Sand 950'

WELL PURPOSE: college  
(home, irrigation, municipal, industrial)

Medium Sand 980'

WELL COMPLETION DATA:

- (1) diameter (inches) 16" O.D.
- (2) total depth (feet) 1431'
- (3) static water level (feet) 218 <sup>below</sup>/<sub>above</sub> top of ground.
- (4) casing Black Stl. 1340'  
(material) (depth)  
if telescope see back.  
(size) 81' 1348'  
(length) (depth to top)
- 8 1/4" Stainless  
(size) (material)
- (6) pump 125 800  
(HP) (yield gpm)  
Electric  
(type power)
- (7) electric log Yes  
(yes or no)  
U.S.G.S.  
(organization running log)
- (8) how well bottom plugged  
Back Pressure Valve

Hard Shale, Streaks  
Lignite, Layers Rock, etc. 1290'  
White W.B. Sand 1316'  
Very Hard Brown Shale 1350'  
Brown Sand and Pea  
Gravel 1434'  
Hard Brown Shale 1502'

**CODED**

MAY 20 1971

DRILLERS REMARKS: "Quality"  
above all else

MISS. BD. OF  
WATER COMM.



If well telescopes please sketch and show depths.

**GROUND LEVEL**


SECTION \_\_\_\_\_

Please indicate well location X.

**ADDITIONAL INFORMATION**

If more than one screen, show locations of each on sketch.