PANOLA
R 2012

# MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources
Southport Mall
P.O. Box 10631
Jackson, Mississippi 39209

## WATER WELL DRILLERS LOG

8-2 19 85 LIFE WELL & SUPPLY PANOLA
date well completed — firm name — county well located

LANDOWNER: KEN BLOODWORTH
QUAIL RUN RD.
BATESVILLE, MS
(mailing address)

WELL LOCATION:
sec 27 T 9 N (S) R 7 E (W)
5 miles E of BATESVILLE
(distance) (direction) (nearest town)

WELL PURPOSE: HOME
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 4
(2) total depth (feet) 150
(3) static water level (feet) 50 below above top of ground.
(4) casing PVC (material), 140 (depth), ____ (size) if telescope see back.
(5) screen 10' (length), 140 (depth to top), 4" (size), PVC (material)
(6) pump 2 (HP) 50 (yield gpm) 230V 1Ø (type power)
(7) electric log NO (yes or no)
(organization running log)
(8) how well bottom plugged CAP

DRILLERS REMARKS:

| description of formations encountered | from | to |
|---|---|---|
| top soil | 0 | 15 |
| Brown C. & sand | 15 | 20 |
| gravel | 20 | 30 |
| sand & clay | 30 | 40 |
| " " | 40 | 60 |
| sand | 60 | 80 |
| sand | 80 | 100 |
| sand | 100 | 120 |
| sand | 120 | 140 |
| sand | 140 | 150 |