

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Pearl River

WELL NUMBER D-2102 CODED

DATE WELL COMPLETED
3-1-01

PERMIT NUMBER

NAME OF DRILLING FIRM
Boneswaterwell

NAME & MAILING ADDRESS OF LANDOWNER
Tammy Turnage
91 Jute Davis Rd
Lumberton, MS 39453

WELL LOCATION: SEC 34 TOWNSHIP 1 RANGE 14 N E W

DISTANCE Le Miles SE of Lumberton

OTHER LANDMARK

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) _____ H/P 1

Pump Capacity (GPM) 5 No. of Stages 2 Setting Depth _____ FT.

PUMP TEST
Well yielded _____ GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth <u>100</u>	Casing Diameter (In.) <u>2</u>	Casing Length (Ft.) <u>90</u>
Type of Casing <u>SCH40</u>	Hole Depth <u>100</u>	Depth to Static Water Level <u>60</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe) _____

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches <u>2</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>#8</u>
Screen Type <u>SCH40</u>	Depth to Bottom - Feet	

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>Sand</u>	<u>0</u>	<u>40</u>
<u>Clay</u>	<u>40</u>	<u>50</u>
<u>Sand</u>	<u>50</u>	<u>100</u>

FORMATIONS (Continued)	FROM	TO

RECD AUG 24 2001

IF MORE SPACE IS NEEDED, USE BACK

