



If well telescopes please sketch and show depths.

GROUND LEVEL

2-

	X		

SECTION 18

Please indicate well location X.

Pump Capacity (GPM)	No. of Stages	Setting Depth
80	15	200 FT.

PUMP TEST

Well yielded 85 GPM with  
 a drawdown of 1 ft.  
 after 10 hours of pumping

LOG DATA

TYPE OF LOG RUN (Circle One):  No Log Run,  Electric,  Gamma Ray,  Density,  Sonic,  Neutron,  Other (Describe) \_\_\_\_\_

Name of Organization Running Log \_\_\_\_\_

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SHP PUMP SET 200' ON  
STEEL PIPE

If more than one screen, show location of each on sketch.