

PERRY

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Bureau of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	
WELL NUMBER	CODED
J 2020	
DATE WELL COMPLETED	
10-11-91	

PERMIT NUMBER
0408
NAME OF DRILLING FIRM
Andy Fogle Well Serv
Wucedale Ms

NAME & MAILING ADDRESS OF LANDOWNER			
Lois Bell			
33 Hwy 15 N.			
Beaumont MS 39423			
WELL LOCATION:	SEC	TOWNSHIP	RANGE
	20	T3	N 089 E
DISTANCE	DIRECTION	NEAREST TOWN	
5	Miles N	of Beaumont	
OTHER LANDMARK			
on Hwy 15 north			
WELL PURPOSE (Home Irrigation, Municipal, Industrial, Fish Pond, etc.)			

PUMP DATA		
PUMP TYPE (Circle One):		
Submersible,	Turbine,	<u>Jet</u> Flowing Well,
Other (Describe)		
POWER TYPE (Circle One):		
<u>Electric</u> Tractor,	Diesel,	Gasoline, Butane,
Other (Describe) H/P		
Pump Capacity (GPM)	No. of Stages	Setting Depth
10	2	30' FT.
PUMP TEST		
Well yielded 15 GPM with		
a drawdown of 0 ft.		
after 4 1/2 hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
40'	2"	35'
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	40	30'
TYPE OF COMPLETION: (Circle One or More):		
Gravel Packed,	Underreamed,	Telescoped,
Natural Development,	Open Hole,	Other
(Describe) <u>air lift</u>		
Top of Lap Pipe or Reduction in casing		
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

LOG DATA	
TYPE OF LOG RUN (Circle One):	
Electric, Gamma Ray, Density, Sonic, Neutron,	No Log Run,
Other (Describe)	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
2"	5'	#8
Screen Type	Depth to Bottom - Feet	
PVC Saver	40'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
top sand	0	5
sandy clay	5	16
sandy clay	16	20
med to coarse sand	20	40

FORMATIONS (Continued)		FROM	TO
PROBATION			
DEC 23 1991			
Dept. of Environmental Quality Bureau of Land & Water Resources			
IF MORE SPACE IS NEEDED, USE BACK			

