

MISSISSIPPI DEPARTMENT OF ENVIRONMENT QUALITY

Office of Land and Water Resources

P.O. Box 2309

Jackson, MS 39225

Water Well Plugging/Decommissioning Form

OLWR-DF-1 (4/08)

A162
A185

COUNTY WELL LOCATED	Pike	WELL NUMBER:	570008-X
PERMIT NUMBER:	MS-GW- 12800 12900	DATE WELL PLUGGED:	07/17/2012
NAME OF FIRM PLUGGED WELL:	Mid-South Water and Machine Works, LLC TELEPHONE NUMBER (662) 843-4076		
NAME AND ADDRESS OF CURRENT LANDOWNER:	North Pike Water Association 705 East Railroad Ave. Summit, MS 39868		
WELL LOCATION	SECTION:	TOWNSHIP:	RANGE:
WELL LOCATION- (LATITUDE)	LONGITUDE	METHOD (CIRCLE ONE): (1) UICRS QUAD (2) CONVENTIONAL SURVEY (3) GPS - HAND HELD OR SURVEY GRADE	
	N31° 18' 21"	W90° 27' 2"	
DISTANCE:	300'	DIRECTION:	North
NEAREST TOWN:	Barnett	OTHER LANDMARK:	on Johnson Station Road
WELL PURPOSE (HOME, IRRIGATION, MUNICIPAL, ETC.):	Rural Water Association		
NAME OF WELL CONTRACTOR WHO DRILLED THE WELL:	Unknown		
NAME OF LANDOWNER WHEN WELL WAS DRILLED:	North Pike Water Association		

WELL DATA			
WELL DEPTH:	165'	BOLE DEPTH:	
CASING DIAMETER (IN)	10"	CASING LENGTH (FT)	125'
		TYPE OF CASING	Steel
DEPTH TO STATIC WATER LEVEL	85'	DATE WELL COMPLETED:	12/1/73
WHY IS THE WELL BEING ABANDONED?	Does not pump water		

DESCRIBE HOW THE WELL OR HOLE WAS PLUGGED (AMOUNT OF CASING AND/OR SCREEN THAT WAS REMOVED OR LEFT IN HOLE MATERIAL AND AMOUNT USED IN PLUGGING, METHOD OF PLACING MATERIAL, ETC.)

No pump in well.

2" pipe run to 140'.

Five cubic yards of cement pumped into well.

Obtained cement returns at ground level.

Removed concrete foundation.

Cut casing off 3' below ground and dressed site.

I CERTIFY THAT THE WELL WAS PLUGGED OR ABANDONED IN ACCORDANCE WITH THE STATE OF MISSISSIPPI REGULATIONS

Clayton Miller PRINT NAME	0-703 MS LICENSE NUMBER
<i>Clayton Miller</i> SIGNATURE	07-28-2012 DATE