

Test hole = log 65

MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

SCOTT  
~~CZG~~  
5-68  
Miss 660-Sur R.

5-27-1968 date well completed  
Lynn-Crestal Company firm name  
Scott county well located

LANDOWNER: H. & H. Water Association, Inc.  
Harperville, Miss  
(mailing address)

WELL LOCATION:  
sec. 33 T. 8N R. 8E  
5 7NS 8CW  
1 miles South of Harperville  
(distance) (direction) (nearest town)

WELL PURPOSE: Domestic  
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 10"
  - (2) total depth (feet) 918'
  - (3) static water level (feet) 116' below top of ground.
  - (4) casing Steel, 857' (material) (depth)  
10" (size) If telescope see back.
  - (5) screen 50', 862' (length) (depth to top)  
6", Stainless Steel (size) (material)
  - (6) pump 50 (HP) (yield gpm)  
Electric (type power)
  - (7) electric log used (yes or no)  
Miss. Geo. Survey (organization running log)
  - (8) how well bottom plugged blue

description of formations encountered	from	to
Top Soil	0	2
Yellow Clay	2	35
Sandy Clay	35	115
Sand	115	176
Clay	176	260
Clay, med. lock.	260	280
Sandy Clay, Sd. of Sand	280	366
Clay	366	384
Sand	384	406
Clay	406	492
Fine Sand	492	492
Shale	492	745
lock	745	748
Shale	748	850
Sandy Clay	850	865
Sand, Shale & Shale	865	912
Shale, Fine Sand	912	919

QPT well

MISS. BOARD OF WATER COMMISSIONERS

DRILLERS REMARKS:  
Power not available - no test run as of this date.

