

STATE WELL REPORT

County: Shackley
 Permit #: GW-49625 ✓
 Driller: Clarene McMurry
 Date drilling completed: 9-23-16

Part I
Driller's Log
 Mississippi Department of Environmental Quality
 Office of Land and Water Resources
 P.O. Box 2309
 Jackson, MS 39225-2309
 (601)961-5210
 (601)360-0535 (fax)

For Office Use Only:
 Well #: C257
 Aquifer: _____
 E-Log #: _____

State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.

Well Owner Information 2405 #1 (Landowner if borehole is not for a water well)		Well or Borehole Location	
Owner Name: <u>JWBMS, LLC</u>		Latitude: <u>32° 58' 08.25"</u> Longitude: <u>90° 54' 03.93"</u>	
Mailing Address: <u>4424 Carolina Hwy</u>		Method of Lat/Long (check one): Conventional Survey _____	
<u>Denmark SC 29042</u>		USGS quad _____, Hand-held GPS <u>X</u> , Survey-grade GPS _____	
City	State	Zip Code	<u>NE 1/4 SE 1/4, Sec 15 T 13N R 07W</u>
Telephone No. <u>(662) 347-8090</u>		<u>4.52</u> Miles <u>North</u> of <u>Rolling Fork</u> (Distance) (Direction) (Nearest Town)	

Well / Borehole Data

Date drilling started: 9-23-16 Date drilling completed: 9-23-16 Hole depth: 125' Hole diameter: 26"

Location of the source of any surface water used for drilling: Hauled from nearby ditch

Method of dosing and volume of Chlorine used in drilling and development: _____

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: _____

Name of organization running log(s): _____

Purpose of borehole (circle one) Water Well Geotechnical/Geological Investigation Ground Source Heat Pump
 Seismic Survey Other (describe) _____

If drilling is not related to water well construction, skip the remainder of this block

Purpose of Well (circle all applicable): Home Industrial Public Supply Irrigation Fish Culture

Other (describe): _____

If a flowing well, method of flow regulation: Valve _____ Other (describe) _____

Static Water Level: 15 feet (above or below land surface (circle one) Date measured: 9-26-16

Method of measurement (circle one): Steel tape Electric tape Air line Other (describe): _____

Well depth: 125' Well grouted to a depth of: 10 feet Type of grout (circle one) Neat Cement Bentonite Mix

Casing length: 75 feet Casing diameter: 16 inches Type of casing: PVC

Screen length: 50 feet Screen diameter: 16 inches Type of screen: PVC

Screen slot size: .050 inches Setting depth: From 75 feet to 125 feet

Type of completion (circle all applicable): Gravel Packed Underreamed Open hole Natural Development

Other (describe): _____

Top of lap pipe or reduction in casing: N/A feet

If telescoped or more than one screen, describe on next page

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
 Mississippi Department of Environmental Quality
 Office of Land and Water Resources
 P.O. Box 2309
 Jackson, MS 39225-2309
 (601)961-5210
 (601) 360-0535 (fax)

For Office Use Only:

Well #: C257
 Aquifer: _____

County: Sharkey
 Permit #: GW-49625
 Driller: Scott Hood
 Date completed: 9-26-16
 Copy information from block on Part 1

This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part I of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.

Well Owner Information		Well Location	
Owner Name: <u>JWBMS, LLC</u>		Latitude: <u>32° 58' 08.25"</u>	Longitude: <u>90° 54' 03.93"</u>
Mailing Address: _____		Method of Lat/Long (check one):	Conventional Survey _____
<u>4424 Carolina Hwy</u>		USGS quad _____	Hand-held GPS <u>X</u> Survey-grade GPS _____
<u>Denmark</u> <u>SC</u> <u>29042</u>		<u>NE</u> 1/4 <u>SE</u> 1/4, Sec <u>15</u> T <u>13N</u> R <u>07W</u>	
City State Zip Code		<u>4.52</u> Miles <u>North</u> of <u>Rolling Fork</u>	
Telephone No. <u>(601) 347-8090</u>		(Distance) (Direction) (Nearest Town)	

Pump Type (circle one)

Submersible Turbine Air Lift Centrifugal Flowing Well Jet Piston Rotary Other (describe): _____

Date Pump Installed: 9-26-16 Rated Pump Capacity: _____ Gallons Per Minute

Is This Pump (circle one): New Repaired Replacement

Power Type (circle one)

Electric Diesel Gasoline Natural Gas Tractor PTO Windmill Other (describe): Bear Drive

Horse Power Rating of Motor: 60 Setting Depth: 80 feet Number of Stages: 1

Pump Test Data for Non Flowing Well

Date Well Tested: NOT TESTED Duration of Pump Test (minimum 4 hours): N/A hours

Static Water Level (A): 15 Feet Below Land Surface Pumping Water Level (B): N/A Feet Below Land Surface

Drawdown [(B) - (A)]: N/A Feet Below Land Surface Test Pumping Rate: N/A Gallons Per Minute

Method of measurement (circle one): Steel tape Electric tape Air line Other (describe): _____

Pump Test Data for Flowing Well

Measured shut in head: _____ feet.

Well yielded _____ GPM with a drawdown of _____ feet after _____ hours of pumping

Meter Installation

Meter Manufacturer: _____ Meter Serial Number: _____

Meter Model Number/Name: _____ Type of Meter: _____

Totalizer Register Unit and Multiplier Factor (AF x .001, gal x 1000, etc): _____

Installation Date: _____ Meter installed by: _____

Is This Meter (circle one): Now Repaired Replacement

Important: By submitting the above information you are certifying that this meter was installed to manufacturer standards. For agricultural wells, a list of approved meters is on the MDEQ website.

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

Clayton Miller 0-703 10-4-16 Clayton Miller
 Print Name of Pump Installer and License No. (if applicable) Date Signature of Pump Installer

STATE OF MISSISSIPPI

Department of Environmental Quality

Office of Land and Water Resources

P. O. Box 2309

Jackson, Mississippi 39225

0257

PERMIT**TO DIVERT OR WITHDRAW FOR BENEFICIAL USE THE PUBLIC WATERS**

This permit is issued to the landowner named below in accordance with the provisions of the Mississippi Water Laws, Mississippi Code Sections 51-3-1, et seq. (1972, as amended), and the regulations and standards as promulgated thereunder. Whether or not specifically named in this permit or in the applications for this permit, anyone using water from the diversion/withdrawal point described below shall do so in compliance with the provisions of this permit. Neither this permit, nor any authority conferred hereby, may be sold, conveyed, encumbered, assigned, or otherwise aliened, for any period of time or under any conditions whatsoever. This permit may not be modified, transferred or revoked without prior action by the Permit Board. Any attempts to modify, transfer or revoke this permit, or to take any other action on this permit, shall be invalid and unenforceable and may result in immediate revocation or suspension of this permit. The holder of this permit shall at all times be responsible for adherence to the terms and conditions of this permit. No agreement between the permit holder and any other party shall affect the obligations and liabilities of the permit holder. Water use under this permit is allowed only when the streamflow, lake level elevation, or static groundwater level (whichever, if any, is applicable) is above the established minimum, pursuant to Mississippi Code Section 51-3-7. Authorization is hereby granted to divert/withdraw water for the beneficial use designated herein, and for no other purpose, subject to the following terms, conditions, and limitations:

Permit Number: MS-GW-49625**Landowner Name:** JWBMS LLC**Landowner Address:** 4424 CAROLINA HIGHWAY
DENMARK SC 29042**Source Of Water:** MISSISSIPPI RIVER VALLEY ALLUVIAL AQUIFER**Beneficial Use:** IRRIGATION**Diversion/Withdrawal Location:** NE 1/4 of the SE 1/4 **Section:** 15 **Township:** 13N **Range:** 27W**County:** SHARKEY**Quad:** ROLLING FORK WEST**Maximum Volume:** 180 Acre-Foot/Year equivalent to .1607 Million Gallons/Day**Maximum Rate:** 2500 Gallons/Minute**Applicant Name:** JWBMS LLC**Applicant Address:** 4424 CAROLINA HIGHWAY
DENMARK SC 29042**Date Permit Issued:** 08/30/2016**Date Permit Expires:** 08/30/2021**Date Permit Modified:****Date Permit Re-Issued:**

This permit shall be deemed null and void if construction has not begun within one (1) year of permit issue date

SPECIAL TERMS AND CONDITIONS:**SPECIAL TERMS AND CONDITIONS 2:** SEE ATTACHMENT 1, WHICH IS HEREBY DECLARED TO BE PART OF THIS PERMIT.


Gary C. Rikard, Executive Director
Mississippi Department of Environmental Quality